

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2012502097
DATE : 23.04.2025
REQ No : 1012502172
REQ TITLE : Potential Transformers
DELIVERY LOCATION : 0014 - G STORE SPAR&CHE
CLOSING DATE : 29.04.2025
CLOSING TIME : 10:00:00

| SL NO | ITEM CODE | SERVICE ID | DESCRIPTION | QTY | UOM | BRAND/ORIGIN | WARRANTY | UNIT PRICE | TOTAL PRICE |
|-------|------------|------------|--|-----|-----|--------------|----------|------------|-------------|
| 1 | 2700136593 | | VOLTAGE TRANSFORMER; RATING: 12KV; VOLTAGE RATIO: 10500/1.73, 110V/1.73; FREQUENCY RATING: 50HZ; BURDEN: 100VA; TYPE: INDOOR; ACCURACY CLASS: 1; MFR: SIEMENS; MPN: 4MQ62XC; VDE 0414 TWO POLE INSULATED; INSULATION LEVEL 12/28/35/75 KV; APPLICATION: GENERATOR BUS DUCT; DWG: VOL12SEC1.2; 4MQ62 XC-Z-002 KKS CODE: 11/12/21/22BAB36 | 3 | EA | | | | |
| 2 | 2700136594 | | VOLTAGE TRANSFORMER; RATING: 12KV; VOLTAGE RATIO: 10500/1.73, 110V/1.73; FREQUENCY RATING: 50HZ; BURDEN: 100VA; TYPE: INDOOR; ACCURACY CLASS: 0.5; MFR: SIEMENS; MPN: 4MQ62XC, VDE 0414: TWO POLE INSULATED; #INSULATION LEVEL 12/28/35/75 KV; APPLICATION: GENERATOR BUS DUCT; DWG: VOL12 SEC1.2; 4MQ62 XC-Z-001 KKS CODE: 11/12/21/22BAB36 | 3 | EA | | | | |
| 3 | 2700136595 | | VOLTAGE TRANSFORMER; RATING: 20KV; VOLTAGE RATIO: 15500/1.73, 110V/1.73; FREQUENCY RATING: 50HZ; BURDEN: 100VA; TYPE: INDOOR; ACCURACY CLASS: 0.5; MFR: RITZ; MPN: GSE20, DIN VDE 0414, 1.9UN 8H; ADDITIONAL INFO: TWOPOLE INSULATED; #INSULATION LEVEL 10/50/125 KV; APPL | 1 | EA | | | | |

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2012502097
DATE : 23.04.2025
REQ No : 1012502172
REQ TITLE : Potential Transformers
DELIVERY LOCATION : 0014 - G STORE SPAR&CHE
CLOSING DATE : 29.04.2025
CLOSING TIME : 10:00:00

| SL NO | ITEM CODE | SERVICE ID | DESCRIPTION | QTY | UOM | BRAND/ORIGIN | WARRANTY | UNIT PRICE | TOTAL PRICE |
|-------|------------|------------|--|-----|-----|--------------|----------|------------|-------------|
| | | | ICATION: GENERATORBUS DUCT; DWG: VOL12 SEC1.2; GSE20, DIN VDE 0414; KKS CODE: 31BAB36 | | | | | | |
| 4 | 2700136596 | | VOLTAGE TRANSFORMER; RATING: 20KV; VOLTAGE RATIO: 15500/1.73, 110V/1.73; FREQUENCY RATING: 50HZ; BURDEN: 100VA; TYPE: INDOOR; ACCURACY CLASS: 1; MFR: #RITZ ; MPN: #GSE20, DIN VDE 0414, 1.9UN 8H; ADDITIONAL INFO: TWOPOLE INSULATED; # INSULATION LEVEL 10/50/125 KV; APPLICATION: GENERATORBUS DUCT; DWG: VOL12 SEC1.2; #GSE20, DIN VDE 0414; KKS CODE: 31BAB36 | 1 | EA | | | | |

TOTAL AMOUNT IN WORDS:

TOTAL AMOUNT:

SPECIAL NOTES / INSTRUCTIONS:

Potential Transformers

STANDARD TERMS & CONDITIONS

- Prices should be 'DDP' delivery duty paid at DEWA stores.
- Quotation to be submitted only in local currency U.A.E Dirhams

MATERIAL AND OR SERVICE PROVIDED TO DEWA SHOULD PREFERABLY BE ENERGY EFFICIENT AND ENVIRONMENT FRIENDLY.

Page2 of 3

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2012502097
DATE : 23.04.2025
REQ No : 1012502172
REQ TITLE : Potential Transformers
DELIVERY LOCATION : 0014 - G STORE SPAR&CHE
CLOSING DATE : 29.04.2025
CLOSING TIME : 10:00:00

3) DEWA Standard payment terms is '30 days credit' from the date of acceptance of material

4) No DEWA staff or his or her relatives up to third degree should have ownership or partnership in your company, and your participation in DEWA tenders / RFQs should not constitute a Conflict or perceived Conflict of Interest.

5) The offered product and/ or services in the Quotation, shall be conforming and in accordance with DEWA Energy Management Policy & EnMS Manual.

SUPPLIER'S REMARKS :

SUPPLIER'S SIGNATURE AND STAMP