

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332500929
DATE : 15.04.2025
REQ No : 1032501502
REQ TITLE : Junction box Replace with ins
DELIVERY LOCATION
CLOSING DATE : 23.04.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
1		ITEM-00001	REPLACEMENT OF JUNCTION BOXA)#REMOVAL OF THE EXISTING DAMAGED JUNCTION BOX WITH INSTRUMENTSUPPORT, & U BEAM AND ACCESSORIES (NUT, BO LT, SWING PIN ETC.)AND THE CO2STATUS INDICATOR INSTRUMENTS TO BE REMOVED FROM EXISTING JB ANDREINSTALLED TO THE NEW JBB)#SUPPLY INST ALLATION OF SUNSHADE & ITS NECESSARY SUPPORTS WITH EPOXYCOATING.#SUNSHADE MATERIALS SHALL BE HOT DIP GALVANIZED WITH EPOXY COATING.# ALL FASTENERS & ACCESSORIES SHALL BE SS316.C)#SUPPLY AND INSTALLATION OF WEATHERPROOF IP66 RATED JUNCTION BOX ANDTHE TECHNICAL DETAI LS AS FOLLOW AS.#MAKE: RITTAL / SCHNEIDER ELECTRIC.#IP66 RATED.#WALL MOUNTED TYPE WITH INDUSTRIAL MULTIPURPOSE ENCLOSURE.#ENCLOSURE WITH BACKPLATE AND ALL NECESSARY ACCESSORIES SHOULD BEINCLUDED AS PER THE BELOW REQUIREMENTS.#MATERIAL SHALL BE	15	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332500929
DATE : 15.04.2025
REQ No : 1032501502
REQ TITLE : Junction box Replace with ins
DELIVERY LOCATION
CLOSING DATE : 23.04.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			SS316 ENCLOSURE-#4- POINT LOCK WITH HANDLE AND 10MM DOUBLE BAR INSERT-#EQUIPPED WITH BASE MOUNTING PLATE IN VERTICAL & HORIZONTAL-#STANDARDS: IEC 60529, 62262,62208 & 62210, NEMA 4X CLASSIFICATION 13,15 & 4X WITH EXPLOSION PROOF, EN 1634-3 & EN-#PRODUCT CERTIFICATIONS: UL & FM APPROVA L-#FIRE RESISTANCE: 960 C WITH 10 HOURS-#AMBIENT TEMPERATURE -35 C TO 120 C-#TEMPERATURE AND UV RESISTANCE FOR OUTDOOR USE-#SHALL B E CAPABLE OF THE APPLICATION AS FIRE RESISTANCE, FIRE LOADINSULATION AND SMOKE PROTECTIOND)#THE ACCESSORIES SHALL BE REPLACED AND SH ALL BE CORROSION RESISTANTAND FIRE RETARDANT.E)#THE MICC CABLE SHROUD,GLAND,POT & SEAL MATERIALS SHOULD BE FROM THEPRYSMIAN (MAKE).. THE CO2 STATUS INDICATOR CARD & LIGHT CONNECTIONS TO BE REMOVED ANDREINSTALLED BACK TO THE NEW BOX AND THE NECESSARY						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332500929
DATE : 15.04.2025
REQ No : 1032501502
REQ TITLE : Junction box Replace with ins
DELIVERY LOCATION
CLOSING DATE : 23.04.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>ACCESSORIES TO BE INCLUDED IN THE OFFER. THE DAMAGED LED ITEMS TO BE REPLACED DURING THE REMOVAL PROCESS F) # THE EXISTING JUNCTION BOX REMOVAL AND REPLACEMENT WORK SHOULD BE CARRIED OUT WITHOUT DISTURBING ANY INSTRUMENTS IN THE JUNCTION BOX & ANY OTHER SYSTEMS IN THE PLANT AND TO BE REPLACED BY VENDOR IF ANY INSTRUMENTS DAMAGED. G) # ALL THE NECESSARY ACCESSORIES SHOULD BE SUPPLIED BY CONTRACTOR H) # IT IS THE CONTRACTOR RESPONSIBILITY TO CARRY OUT A SITE SURVEY TO VERIFY THE EXACT QUANTITIES AND DIMENSIONS MENTIONED IN THE SCOPE AND TO GET THE DISCREPANCIES CORRECTED IN ADVANCE BEFORE ORDERING. THE CONTRACTOR SHALL SUBMIT THE SPECIFICATIONS AND DRAWINGS OF THE EQUIPMENT'S FOR DEWA APPROVAL BEFORE FINALIZATION OF THE ORDER. I) # THE COMPLETE HANDLING OF THE</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332500929
DATE : 15.04.2025
REQ No : 1032501502
REQ TITLE : Junction box Replace with ins
DELIVERY LOCATION
CLOSING DATE : 23.04.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			MATERIALS INCLUDING TRANSPORT FROM SHOPTO SITE, LOADING AND UNLOADING, STORING AT SITE TILL THE INSTALLATIONSHALL BE DONE BY THE CONTRACTOR AT HIS COST AND RESPONSIBILITY.J)#ANY REPLACED PART S/SCRAP, WHICH IS NOT REQUIRED BY DEWA SHALL BEREMOVED FROM SITE. THE DISPOSAL IS THE CONTRACTOR RESPONSIBILITY. THEOTHER MATERIALS, SCRAPS OF THE REPLACED EQUIPMENT, WHICH DEWA REQUIRESARE TO BE TRANSFERRED TO THE ASSIGNED STATION LOCATION BY THECONTRACTOR. ANY P LACE, WHERE OLD EQUIPMENT HAD BEEN REMOVED, MUST BECLEANED FOR GOOD HOUSEKEEPING.K)#IT IS THE CONTRACTOR#S RESPONSIBILITY TO ENSURE THAT THE REPLACEMENTSHOULD PROVIDE CONVENIENCE OF OPERATION AND MAINTENANCE, NEAT ANDORDERLY ARRANGEMENT WHICH CONSIDERS THE FUNCTIO NAL REQUIREMENTS AND GOODAESTHETIC						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332500929
DATE : 15.04.2025
REQ No : 1032501502
REQ TITLE : Junction box Replace with ins
DELIVERY LOCATION
CLOSING DATE : 23.04.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			LOOK.L)#THE TAG NO. OR THE SERVICE DESCRIPTION OR THE KKS CODE ENCRYPTEDPLATES (SS316) SHALL BE FIXED ON THE NEW JBS.M)#THE CABLE TAG SHOULD BE PROVIDED AND SHOULD BE INDUSTRIAL TYPEN)#THE SCAFFOLDING WHEREVER REQUIRED, SHALL BE DONE BY THE CONTRACTOR.THE CONTRACTOR MUST CAREFULLY UNINSTALL AND INSTALL THE EQUIPMENT FORTHIS PROJECT. IT IS THE CONTRACTOR#S SOL E RESPONSIBILITY TO ENSURE THATNO DISTURBANCE, INTERFERENCE, OR INTERRUPTION TO BE CAUSED ON NORMALPLANT OPERATION. ANY DAMAGE TO TH E EQUIPMENT DURING THE EXECUTION WORKSHALL BE RESTORED IMMEDIATELY BY THE CONTRACTOR WITH THE SAME MATERIAL.O)#ANY UNFORESEEN OR ADD ITIONAL EXPENSES INCURRED FOR THE FULL FUNCTION/ COMPLETION OF THE INTENDED JOB ALLOTTED TO THE CONTRACTOR SHALL BE UNDER HIS SCOPE A						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332500929
DATE : 15.04.2025
REQ No : 1032501502
REQ TITLE : Junction box Replace with ins
DELIVERY LOCATION
CLOSING DATE : 23.04.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>ND USE NEW AREA AS PROPOSED BY DEWA IF NOT ABLE TO USE EXISTING PLACE.P)#ON RECEIVING CONFIRMED PURCHASE ORDER FROM DEWA, CONTRACTOR SHALL PROVIDE DETAILED SCHEDULE IN MS PROJECT FORMAT HIGHLIGHTING SUPPLY AND IMPLEMENTATION OF TOTAL WORK. NECESSARY DOCUMENTS / CERT IFICATES / DATA SHEETS FOR THE SUPPLIED MATERIAL SHALL BE PROVIDED FOR APPROVAL.Q)#ALL THE ACTIVITIES MENTIONED IN THE SCOPE ARE TO BE CARRIED OUT BASED ON THE PLANT UNDER OPERATING CONDITIONS. THEREFORE, THE SERVICE WORK ACTIVITIES SHALL BE DONE WITH UTMOST CARE AND IN A SAFE MANNER TO AVOID ANY DISTURBANCE IN THE PLANT.R)#THE PROJECT SHALL BE COMPLETED AND HANDED OVER TO DEWA AT THE SHORTEST POSSI BLE TIME.S)#THE CONTRACTOR SHALL ABIDE BY THE PREVAILING SAFETY AND SECURITY RULES AND REGULATIONS IN FORCE AT DEWA JEBEL ALI</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332500929
DATE : 15.04.2025
REQ No : 1032501502
REQ TITLE : Junction box Replace with ins
DELIVERY LOCATION
CLOSING DATE : 23.04.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>POWER S TATION.T)#THE DEDICATED SAFETY OFFICER AND ENGINEER SHOULD BE AVAILABLE DURINGTHE WORK.U)#THE CONTRACTOR SHALL BE LIABLE FOR ALL POS SIBLE DAMAGES TO THEEQUIPMENT AND PERSONS WORKING DURING THE EXECUTION OF THE CONTRACT.V)#DEWA WILL NOT PROVIDE ANY SUPPORT / MATERI ALS / CONSUMABLE TOCOMPLETE THIS JOB AND ALL THE WORKS FULLY RESPONSIBLE BY CONTRACTOR.W)#THE MATERIAL TEST CONFORMITY CERTIFICATE & ORIGIN CERTIFICATE SHOULD BE PROVIDED BEFORE OBTAINING THE APPROVAL.X)#THE CONTRACTOR SHALL PROVIDE A MATERIAL SUPPLY WARRANTY OF 5 YEARSAND SERVICE WARRANTY OF 1 YEARS FOR THE WORK PERFORMED.CONTACT:RAMESH KUMAR RRAMESH.R@DEWA.GOV.AE</p>						

TOTAL AMOUNT IN WORDS:

TOTAL AMOUNT:

SPECIAL NOTES / INSTRUCTIONS:

MATERIAL AND OR SERVICE PROVIDED TO DEWA SHOULD PREFERABLY BE ENERGY EFFICIENT AND ENVIRONMENT FRIENDLY.

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332500929
DATE : 15.04.2025
REQ No : 1032501502
REQ TITLE : Junction box Replace with ins
DELIVERY LOCATION
CLOSING DATE : 23.04.2025
CLOSING TIME : 10:00:00

Junction box Replace with installation

STANDARD TERMS & CONDITIONS

- 1) Prices should be 'DDP' delivery duty paid at DEWA stores.
- 2) Quotation to be submitted only in local currency U.A.E Dirhams
- 3) DEWA Standard payment terms is '30 days credit' from the date of acceptance of material
- 4) No DEWA staff or his or her relatives up to third degree should have ownership or partnership in your company, and your participation in DEWA tenders / RFQs should not constitute a Conflict or perceived Conflict of Interest.
- 5) The offered product and/ or services in the Quotation, shall be conforming and in accordance with DEWA Energy Management Policy & EnMS Manual.

SUPPLIER'S REMARKS :

SUPPLIER'S SIGNATURE AND STAMP

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332500929
DATE : 15.04.2025
REQ No : 1032501502
REQ TITLE : Junction box Replace with ins
DELIVERY LOCATION
CLOSING DATE : 23.04.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
1		ITEM-00001	REPLACEMENT OF JUNCTION BOXA)#REMOVAL OF THE EXISTING DAMAGED JUNCTION BOX WITH INSTRUMENTSUPPORT, & U BEAM AND ACCESSORIES (NUT, BO LT, SWING PIN ETC.)AND THE CO2STATUS INDICATOR INSTRUMENTS TO BE REMOVED FROM EXISTING JB ANDREINSTALLED TO THE NEW JBB)#SUPPLY INST ALLATION OF SUNSHADE & ITS NECESSARY SUPPORTS WITH EPOXYCOATING.#SUNSHADE MATERIALS SHALL BE HOT DIP GALVANIZED WITH EPOXY COATING.# ALL FASTENERS & ACCESSORIES SHALL BE SS316.C)#SUPPLY AND INSTALLATION OF WEATHERPROOF IP66 RATED JUNCTION BOX ANDTHE TECHNICAL DETAI LS AS FOLLOW AS.#MAKE: RITTAL / SCHNEIDER ELECTRIC.#IP66 RATED.#WALL MOUNTED TYPE WITH INDUSTRIAL MULTIPURPOSE ENCLOSURE.#ENCLOSURE WITH BACKPLATE AND ALL NECESSARY ACCESSORIES SHOULD BEINCLUDED AS PER THE BELOW REQUIREMENTS.#MATERIAL SHALL BE	15	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332500929
DATE : 15.04.2025
REQ No : 1032501502
REQ TITLE : Junction box Replace with ins
DELIVERY LOCATION
CLOSING DATE : 23.04.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>SS316 ENCLOSURE-#4- POINT LOCK WITH HANDLE AND 10MM DOUBLE BAR INSERT-#EQUIPPED WITH BASE MOUNTING PLATE IN VERTICAL & HORIZONTAL-#STANDARDS: IEC 60529, 62262,62208 & 62210, NEMA 4X CLASSIFICATION 13,15 & 4X WITH EXPLOSION PROOF, EN 1634-3 & EN-#PRODUCT CERTIFICATIONS: UL & FM APPROVA L-#FIRE RESISTANCE: 960 C WITH 10 HOURS-#AMBIENT TEMPERATURE -35 C TO 120 C-#TEMPERATURE AND UV RESISTANCE FOR OUTDOOR USE-#SHALL B E CAPABLE OF THE APPLICATION AS FIRE RESISTANCE, FIRE LOADINSULATION AND SMOKE PROTECTIOND)#THE ACCESSORIES SHALL BE REPLACED AND SH ALL BE CORROSION RESISTANTAND FIRE RETARDANT.E)#THE MICC CABLE SHROUD,GLAND,POT & SEAL MATERIALS SHOULD BE FROM THEPRYSMIAN (MAKE).. THE CO2 STATUS INDICATOR CARD & LIGHT CONNECTIONS TO BE REMOVED ANDREINSTALLED BACK TO THE NEW BOX AND THE NECESSARY</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332500929
DATE : 15.04.2025
REQ No : 1032501502
REQ TITLE : Junction box Replace with ins
DELIVERY LOCATION
CLOSING DATE : 23.04.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>ACCESSORIES TO BE INCLUDED IN THE OFFER. THE DAMAGED LED ITEMS TO BE REPLACED DURING THE REMOVAL PROCESS F) # THE EXISTING JUNCTION BOX REMOVAL AND REPLACEMENT WORK SHOULD BE CARRIED OUT WITHOUT DISTURBING ANY INSTRUMENTS IN THE JUNCTION BOX & ANY OTHER SYSTEMS IN THE PLANT AND TO BE REPLACED BY VENDOR IF ANY INSTRUMENTS DAMAGED. G) # ALL THE NECESSARY ACCESSORIES SHOULD BE SUPPLIED BY CONTRACTOR H) # IT IS THE CONTRACTOR'S RESPONSIBILITY TO CARRY OUT A SITE SURVEY TO VERIFY THE EXACT QUANTITIES AND DIMENSIONS MENTIONED IN THE SCOPE AND TO GET THE DISCREPANCIES CORRECTED IN ADVANCE BEFORE ORDERING. THE CONTRACTOR SHALL SUBMIT THE SPECIFICATIONS AND DRAWINGS OF THE EQUIPMENT'S FOR DEWA APPROVAL BEFORE FINALIZATION OF THE ORDER. I) # THE COMPLETE HANDLING OF THE</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332500929
DATE : 15.04.2025
REQ No : 1032501502
REQ TITLE : Junction box Replace with ins
DELIVERY LOCATION
CLOSING DATE : 23.04.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			MATERIALS INCLUDING TRANSPORT FROM SHOPTO SITE, LOADING AND UNLOADING, STORING AT SITE TILL THE INSTALLATIONSHALL BE DONE BY THE CONTRACTOR AT HIS COST AND RESPONSIBILITY.J)#ANY REPLACED PART S/SCRAP, WHICH IS NOT REQUIRED BY DEWA SHALL BEREMOVED FROM SITE. THE DISPOSAL IS THE CONTRACTOR RESPONSIBILITY. THEOTHER MATERIALS, SCRAPS OF THE REPLACED EQUIPMENT, WHICH DEWA REQUIRESARE TO BE TRANSFERRED TO THE ASSIGNED STATION LOCATION BY THECONTRACTOR. ANY P LACE, WHERE OLD EQUIPMENT HAD BEEN REMOVED, MUST BECLEANED FOR GOOD HOUSEKEEPING.K)#IT IS THE CONTRACTOR#S RESPONSIBILITY TO ENSURE THAT THE REPLACEMENTSHOULD PROVIDE CONVENIENCE OF OPERATION AND MAINTENANCE, NEAT ANDORDERLY ARRANGEMENT WHICH CONSIDERS THE FUNCTIO NAL REQUIREMENTS AND GOODAESTHETIC						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332500929
DATE : 15.04.2025
REQ No : 1032501502
REQ TITLE : Junction box Replace with ins
DELIVERY LOCATION
CLOSING DATE : 23.04.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			LOOK.L)#THE TAG NO. OR THE SERVICE DESCRIPTION OR THE KKS CODE ENCRYPTEDPLATES (SS316) SHALL BE FIXED ON THE NEW JBS.M)#THE CABLE TAG SHOULD BE PROVIDED AND SHOULD BE INDUSTRIAL TYPEN)#THE SCAFFOLDING WHEREVER REQUIRED, SHALL BE DONE BY THE CONTRACTOR.THE CONTRACTOR MUST CAREFULLY UNINSTALL AND INSTALL THE EQUIPMENT FORTHIS PROJECT. IT IS THE CONTRACTOR#S SOL E RESPONSIBILITY TO ENSURE THATNO DISTURBANCE, INTERFERENCE, OR INTERRUPTION TO BE CAUSED ON NORMALPLANT OPERATION. ANY DAMAGE TO TH E EQUIPMENT DURING THE EXECUTION WORKSHALL BE RESTORED IMMEDIATELY BY THE CONTRACTOR WITH THE SAME MATERIAL.O)#ANY UNFORESEEN OR ADD ITIONAL EXPENSES INCURRED FOR THE FULL FUNCTION/ COMPLETION OF THE INTENDED JOB ALLOTTED TO THE CONTRACTOR SHALL BE UNDER HIS SCOPE A						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332500929
DATE : 15.04.2025
REQ No : 1032501502
REQ TITLE : Junction box Replace with ins
DELIVERY LOCATION
CLOSING DATE : 23.04.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>ND USE NEW AREA AS PROPOSED BY DEWA IF NOT ABLE TO USE EXISTING PLACE.P)#ON RECEIVING CONFIRMED PURCHASE ORDER FROM DEWA, CONTRACTOR SHALL PROVIDE DETAILED SCHEDULE IN MS PROJECT FORMAT HIGHLIGHTING SUPPLY AND IMPLEMENTATION OF TOTAL WORK. NECESSARY DOCUMENTS / CERT IFICATES / DATA SHEETS FOR THE SUPPLIED MATERIAL SHALL BE PROVIDED FOR APPROVAL.Q)#ALL THE ACTIVITIES MENTIONED IN THE SCOPE ARE TO BE CARRIED OUT BASED ON THE PLANT UNDER OPERATING CONDITIONS. THEREFORE, THE SERVICE WORK ACTIVITIES SHALL BE DONE WITH UTMOST CARE AND IN A SAFE MANNER TO AVOID ANY DISTURBANCE IN THE PLANT.R)#THE PROJECT SHALL BE COMPLETED AND HANDED OVER TO DEWA AT THE SHORTEST POSSI BLE TIME.S)#THE CONTRACTOR SHALL ABIDE BY THE PREVAILING SAFETY AND SECURITY RULES AND REGULATIONS IN FORCE AT DEWA JEBEL ALI</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332500929
DATE : 15.04.2025
REQ No : 1032501502
REQ TITLE : Junction box Replace with ins
DELIVERY LOCATION
CLOSING DATE : 23.04.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>POWER S TATION.T)#THE DEDICATED SAFETY OFFICER AND ENGINEER SHOULD BE AVAILABLE DURINGTHE WORK.U)#THE CONTRACTOR SHALL BE LIABLE FOR ALL POS SIBLE DAMAGES TO THEEQUIPMENT AND PERSONS WORKING DURING THE EXECUTION OF THE CONTRACT.V)#DEWA WILL NOT PROVIDE ANY SUPPORT / MATERI ALS / CONSUMABLE TOCOMPLETE THIS JOB AND ALL THE WORKS FULLY RESPONSIBLE BY CONTRACTOR.W)#THE MATERIAL TEST CONFORMITY CERTIFICATE & ORIGIN CERTIFICATE SHOULD BE PROVIDED BEFORE OBTAINING THE APPROVAL.X)#THE CONTRACTOR SHALL PROVIDE A MATERIAL SUPPLY WARRANTY OF 5 YEARSAND SERVICE WARRANTY OF 1 YEARS FOR THE WORK PERFORMED.CONTACT:RAMESH KUMAR RRAMESH.R@DEWA.GOV.AE</p>						

TOTAL AMOUNT IN WORDS:

TOTAL AMOUNT:

SPECIAL NOTES / INSTRUCTIONS:

MATERIAL AND OR SERVICE PROVIDED TO DEWA SHOULD PREFERABLY BE ENERGY EFFICIENT AND ENVIRONMENT FRIENDLY.

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332500929
DATE : 15.04.2025
REQ No : 1032501502
REQ TITLE : Junction box Replace with ins
DELIVERY LOCATION
CLOSING DATE : 23.04.2025
CLOSING TIME : 10:00:00

Junction box Replace with installation

STANDARD TERMS & CONDITIONS

- 1) Prices should be 'DDP' delivery duty paid at DEWA stores.
- 2) Quotation to be submitted only in local currency U.A.E Dirhams
- 3) DEWA Standard payment terms is '30 days credit' from the date of acceptance of material
- 4) No DEWA staff or his or her relatives up to third degree should have ownership or partnership in your company, and your participation in DEWA tenders / RFQs should not constitute a Conflict or perceived Conflict of Interest.
- 5) The offered product and/ or services in the Quotation, shall be conforming and in accordance with DEWA Energy Management Policy & EnMS Manual.

SUPPLIER'S REMARKS :

SUPPLIER'S SIGNATURE AND STAMP