

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332500965
DATE : 18.04.2025
REQ No : 1032501844
REQ TITLE : PRJ-AUXB 60 tube leak rectifi
DELIVERY LOCATION
CLOSING DATE : 02.05.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
1		ITEM-00001	DHGT251659264FLAYOUTINCELL1FALLOWOVERLAP 1FBEHINDDOCUMENT0FHIDDEN0FLAYOUTINCELL1 DEWA- CONFIDENTIALDHGT251660288FLAYOUTINCELL1FA LLOWOVE RLAP1FBEHINDDOCUMENT0FHIDDEN0FLAYOUTINC ELL1DEWA-CONFIDENTIALTITLE: AUXB 60 TUBE LEAK RECTIFICATION AT M STATION, DEWA, JEBEL ALI.A.# QUANTITY: #SERVICE LINE ITEM-1: BEND TUBE REPLACEMENT INCLUDING BENDING &SWAGING OF TUBE AND COMPLETE REFRACTORY BOX CUTTING & REINS TATEMENT # 01QTY: #SERVICE LINE ITEM-2: STRAIGHT TUBE REPLACEMENT # 01 QTY: #SERVICE LINE ITEM-3: ADDITIONAL BEND TUBE REPLACEMENT (IF REQUIREDBASED ON SITE FINDINGS) # 01 QTY: #SERVICE LINE ITEM-4: ADDITIONAL STRAIGHT TUBE REPLACEMENT (IFREQUIRED BASED ON SITE FINDI NGS) # 01 QTYNOTE: PAYMENT WILL BE MADE BASED ON THE ACTUAL QUANTITY OF WORK DONE	1	LS				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332500965
DATE : 18.04.2025
REQ No : 1032501844
REQ TITLE : PRJ-AUXB 60 tube leak rectifi
DELIVERY LOCATION
CLOSING DATE : 02.05.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>AT THE SITE ACCORDING TO THE TUBE LEAK LOCATION.B.#</p> <p>SPECIFICATION.#TUBE MATERIAL: SA210-A1 / SA210-C.#TUBE SIZE: 76.2MM X 3.6</p> <p>MMC.#DURATION:.#FOR BEND TUBE REPLACEMENT INSIDE REFRACTOR</p> <p>Y BOX: 04 DAYS.#FOR STRAIGHT TUBE REPLACEMENT OUTSIDE REFRACTORY BOX: 02 DAYS</p> <p>SD.#SCHEDULE.#WORK TO BE STARTED WITHIN 01 DAY OF ADVANCE NOTICE.E.#PRE-BID SITE INSPECTION:.#THE CONTRACTOR SHALL VISIT THE SITE AND MAKE THEMSELVES FULLY FAMILIAR WITH THE WORK SCOPE, PLANT ACCESS, FACILITIES, COMPLEXITIES, ETC., BEFORE SUBMITTING THE BID. DEWA WILL NOT ACCEPT ANY CLAIM FOR EXTRAS BEYOND THE ORDER RATES</p> <p>/ PRICES DURING AND AFTER THE EXECUTION OF WORK ORDERED.F.#QUALIFICATION OF BIDDER:.#THE BIDDER SHALL HAVE PROVEN EXPERIENCE FOR SIMILAR JOBS AND SHALL SUBMIT EVIDENCE.#THE</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332500965
DATE : 18.04.2025
REQ No : 1032501844
REQ TITLE : PRJ-AUXB 60 tube leak rectifi
DELIVERY LOCATION
CLOSING DATE : 02.05.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>BIDDER SHALL BE A VALID ASME #R# STAMP HOLDERG.#SCOPE OF WORK:I.#PREPARATION WORK1.#MOBILIZ E MEN/EQUIPMENT WITHIN 01 DAY AFTER ORDER CONFIRMATION2.#WORK TO BE CARRIED OUT ROUND THE CLOCK IN DOUBLE SHIFTS.3.#OBTAIN PTW (PERM IT TO WORK) / LC (LINE CLEARANCE) FROM DEWA.4.#THE FOLLOWING DOCUMENTS ARE TO BE SUBMITTED TO OBTAIN PTW,4.1.#METHOD STATEMENT4.2.#R ISK ASSESSMENT OF THE WORK4.3.#TOOLBOX TALK REPORT.5.#ENSURE PROPER ISOLATION OF THE LINE & VALID HWP IS AVAILABLE.6.#ENSURE NO FLAM MABLE MATERIALS NEAR THE HOT WORK AREA.7.#ENSURE THE AREA IS CORRECTLY SECURED AND SAFE TO WORK ON IN ALLRESPECTS.8.#CONDUCT SITE SU RVEY AND SAFETY INSPECTION TO ASSESS THE WORKINGENVIRONMENT.9.#IF THE WORKING ENVIRONMENT IS SAFE, YOU CAN PROCEED WITH THEFOLLOWING</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332500965
DATE : 18.04.2025
REQ No : 1032501844
REQ TITLE : PRJ-AUXB 60 tube leak rectifi
DELIVERY LOCATION
CLOSING DATE : 02.05.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>STEPS.II.#BEND TUBE REPLACEMENT AFTER CUTTING REFRACTORY BOX1.#REMOVE THE CLADDING SHEET & INSULATION.2.#CUT AND REMOVE THE WHOLE REFRACTORY BOX.3.#REMOVE CASTABLE REFRACTORY AND REFRACTORY BRICKS.4.#IDENTIFY & MARK THE LEAKING TUBE ALONG WITH DEWA.5.#CUT THE TUBE FINS.6.#CUT THE FAILED TUBE.7.#COLLECT STRAIGHT TUBE FROM DEWA AND BEND IT AS PER OLD SAMPLE.8.#OPEN STEAM DRUM MANHOLE (DEWA SCOP E)9.#CUT & REMOVE BAFFLE PLATE IN THE STEAM DRUM AND PUNCH OUT THE FAILED TUBE.10.#TRANSPORT THE FAILED TUBE AND NEW TUBE FOR REPLACEMENT TO CONTRACTOR WORKSHOP.11.#BEND AND SWAGE THE NEW TUBE AS PER SAMPLE FAILED TUBE.12.#RETURN THE PREFABRICATED BEND TUBE.13.#PWHT AFTER TUBE SWAGING. (NDE WILL BE ARRANGED BY DEWA)14.#FIT UP THE PREFABRICATED BEND TUBE.15.#PREPARE FOR HALF SPLIT INSERT</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332500965
DATE : 18.04.2025
REQ No : 1032501844
REQ TITLE : PRJ-AUXB 60 tube leak rectifi
DELIVERY LOCATION
CLOSING DATE : 02.05.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			REPAIR MET HOD (WINDOW REPAIR) ANDWELD THE TUBE.16.#RT OF THE WELDED JOINTS. (NDE WILL BE ARRANGED BY DEWA)17.#EXPAND TUBE TOP END INSIDE THE S TEAM DRUM.18.#REINSTALL THE REMOVED BAFFLE PLATES.19.#WELD THE FINS BACK IF THEY ARE REMOVED. (IF NEW PLATE REQUIRED FORFINS, THEN T O BE SUPPLIED BY CONTRACTOR)20.#INSTALL BACK THE BRICKS.21.#INSTALL CASTABLE REFRACTORY (TO BE SUPPLIED BY CONTRACTOR AS PEREXISTING REFRACTORY SPECIFICATION).22.#REINSTATE THE REFRACTORY BOX WITH #V# TYPE EXPANSION FOLD,MATERIAL: ASTM A387 GRADE P22. (IF AN OLD B OX OR EXPANSION FOLD IS FOUNDDAMAGED, THEN THE SAME IS TO BE REPLACED)23.#REINSTALL ROCKWOOL INSULATION, IF OLD INSULATION IS FOUND DAMAGED,THEN SAME TO BE REPLACED.24.#REINSTALL CLADDING SHEET, IF						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332500965
DATE : 18.04.2025
REQ No : 1032501844
REQ TITLE : PRJ-AUXB 60 tube leak rectifi
DELIVERY LOCATION
CLOSING DATE : 02.05.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>OLD SHEETS ARE FOUND DAMAGED, THEN SAME TO BE REPLACED.25.#HYDROTEST AT SERVICE PRESSURE (DEWA SCOPE)III.#STRAIGHT TUBE REPLACEMENT1.#REMOVE THE CLADDING SHEET & INSULATION.2.#IDENTIFY & MARK THE LEAKING TUBE ALONG WITH DEWA3.#CUT THE TUBE FINS4.#CUT THE FAILED TUBE.5.#PREPARE FOR HALF SPLIT INSERT REPAIR METHOD (WINDOW REPAIR) A</p> <p>ND WELD THE TUBE6.#RT OF THE WELDED JOINTS. (NDE WILL BE ARRANGED BY DEWA)7.#WELD THE FINS BACK.8.#REINSTALL ROCKWOOL INSULATION, IF</p> <p>OLD INSULATION IS FOUND DAMAGED, THEN SAME TO BE REPLACED.9.#REINSTALL CLADDING SHEET, IF OLD SHEETS ARE FOUND DAMAGED, THEN SAME TO BE REPLACED.10.#HYDROTEST AT SERVICE PRESSURE (DEWA SCOPE)IV.#GENERAL CONDITIONS1.#A QUALIFIED JOB SUPERVISOR SHALL BE ASSIGNED FOR THE JOB.2.#QUALIFIED & SKILLED FABRICATORS/</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332500965
DATE : 18.04.2025
REQ No : 1032501844
REQ TITLE : PRJ-AUXB 60 tube leak rectifi
DELIVERY LOCATION
CLOSING DATE : 02.05.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			MASONS TO CARRY OUT ALL THE JOBS.3.#HOUSEKEEPING AND DISPOSAL OF WASTE SHALL BE DONE AS PER DEWA RULESON A DAILY BASIS.4.#HAZARDOUS & NON-HAZARDOUS TO BE SEPARATED BEFORE DISPOSAL.5.#DE-MOBILIZE MEN AND EQUIPMENT AFTER COMPLETION OF THE JOB.6.#COMPLETION REPORT WITH PHOTOS TO BE SUBMITTED TO DEWA WITHIN 02 DAYS AFTER JOB COMPLETION.7.#ALL TOOLS & TACKLES ARE IN THE CONTRACTOR#S SCOPE.8.#VALID TEST CERTIFICATES OF ALL LIFTING TOOLS, ELECTRICAL TOOLS/CABLES, AND GAS CYLINDERS/HOSES TO BE SUBMITTED BEFORE START OF WORK.9.#VALID CALIBRATION CERTIFICATE OF THE WELDING MACHINES TO BE SUBMITTED BEFORE WORK STARTS.10.#WPS , PQR & WELDER QUALIFICATION CERTIFICATES TO BE SUBMITTED BEFORE THE START OF WORK.11.#ALL WELDING IS TO BE CARRIED OUT BY QUALIFIED						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332500965
DATE : 18.04.2025
REQ No : 1032501844
REQ TITLE : PRJ-AUXB 60 tube leak rectifi
DELIVERY LOCATION
CLOSING DATE : 02.05.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>WELDER AND AS PER WPSIN ACCORDANCE WITH REQUIREMENTS OF ASME CODE.12.#DEWA# SCOPE: -12.1.#INSTALLATION OF SCAFFOLDING12.2.#SUPPLY OF ASTM A387 GRADE P22 PLATE (IF REQUIRED)12.3.#SPARE TUBE FOR REPLACEMENT12.4.#NDE12.5.#ROCKWOOL & CLADDING SHEET, IF REQUIRED.12.6.# DRUM MANHOLE OPENING & CLOSING, IF REQUIRED.12.7.#PWHT OF THE TUBE AFTER SWAGING.H.#WARRANTY.#THE WARRANTY PERIOD FOR THE WORK SHALL BE 01 YEAR FROM THE DATE OFCOMPLETION OF WORK CERTIFIED BY DEWA.#IN CASE OF ANY DAMAGE/DEFECT OF THE WORK CARRIED OUT UNDER THISCO NTRACT WITHIN THIS WARRANTY PERIOD, THE CONTRACTOR SHALL ATTEND ANDCARRY OUT THE NECESSARY REPAIR WORK AND RECTIFY THE DEFECT WITHIN A SHORT PERIOD.I.#GENERAL TERMS & CONDITIONS.#CONTRACTOR SHALL HAVE PREVIOUS WORK EXPERIENCE FOR THE SIMILAR</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332500965
DATE : 18.04.2025
REQ No : 1032501844
REQ TITLE : PRJ-AUXB 60 tube leak rectifi
DELIVERY LOCATION
CLOSING DATE : 02.05.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>JOB.#CONTRACTOR SHALL S UBMIT METHOD OF STATEMENT AND SCHEDULE UPON ORDERCONFIRMATION.#ALL TRANSPORTING AND REQUIRED EQUIPMENT SHOULD BE ARRANGED BY THECON TRACTOR. THIS EQUIPMENT SHOULD BE DULY TESTED AND CERTIFIED BY THE3RD PARTY INSPECTION AGENCY AND THE CERTIFICATES SHOULD BE PRODUCE D ONDEMAND. QUALIFIED MECHANICS SHOULD BE PROVIDED.#THE CONTRACTOR SHALL VISIT THE SITE AND MAKE HIMSELF FULLY FAMILIARWITH THE WOR K SCOPE, PLANT ACCESS, FACILITIES, COMPLEXITIES, SAFETYMEASURES ETC., BEFORE HE SUBMITS HIS BID.#THE CONTRACTOR SHALL ENSURE HOUSEK EEPING ON A DAILY BASIS AND THECONTRACTOR SHALL BE RESPONSIBLE FOR ALL WASTE MATERIAL DISPOSAL TODESIGNATED PLACES.#ALL DEWA SAFETY & ENVIRONMENT POLICY, RULES AND REGULATIONS SHALL BEFOLLOWED AT THE WORK</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332500965
DATE : 18.04.2025
REQ No : 1032501844
REQ TITLE : PRJ-AUXB 60 tube leak rectifi
DELIVERY LOCATION
CLOSING DATE : 02.05.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>SITE DURING THE EXECUTION OF THE WORK. THE CONTRACTOR#S ENG INEER SHOULD BE FAMILIAR WITH SAFETY REGULATIONS WHILE WORKING IN A HAZARDOUS AREA.#SCAFFOLDING IF REQUIRED SHALL BE ARRANGED BY DEW A.#THE WORK SHALL BE EXECUTED UNDER DEWA SUPERVISION AND AS PER QUALITY/SCHEDULE REQUIREMENT.#THE CONTRACTOR#S SUPERVISOR SHALL BE AVAILABLE AT SITE THROUGHOUT THE PERIOD OF WORK.#DEWA WILL ARRANGE NECESSARY PTW / LC / HWP FROM OPERATION, CHEMICAL LAB / FIRE DEPART MENT CLEARANCES TO CARRY OUT THE SCOPE OF WORK UNDER THIS CONTRACT.#THE CONTRACTOR UPON RECEIVING THE WORK PERMIT SHALL FIRST ENSURE A SAFE WORKING CONDITION.#ALL THE PERSONS SHOULD WEAR ALL THE REQUIRED PPE WHILE AT WORK.#ALL MATERIAL AND TOOLS BROUGHT IN SHALL BE DECLARED AT THE POWER STATION SECURITY</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332500965
DATE : 18.04.2025
REQ No : 1032501844
REQ TITLE : PRJ-AUXB 60 tube leak rectifi
DELIVERY LOCATION
CLOSING DATE : 02.05.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			GATE AND THE LIST OF THESE ITEMS SHALL BE SIGNED BYDEWA SECURITY. THE COPIES OF THESE DOCU MENTS SHALL BE LODGED WITH THEDEWA ENGINEER IN CHARGE ON DAILY BASIS. THIS DOCUMENT WILL BE THE BASISFOR THE CLEARANCE (GATE PASS) T O TAKE THEM OUT ON COMPLETION OF THE JOB.SERVICE AIR, ELECTRICITY AND WAT						
2		ITEM-00001	DHGT251659264FLAYOUTINCELL1FALLOWOVERLAP 1FBEHINDDOCUMENT0FHIDDEN0FLAYOUTINCELL1 DEWA- CONFIDENTIALDHGT251660288FLAYOUTINCELL1FA LLOWOVE RLAP1FBEHINDDOCUMENT0FHIDDEN0FLAYOUTINC ELL1DEWA-CONFIDENTIALTITLE: AUXB 60 TUBE LEAK RECTIFICATION AT M STATION, DEWA, JEBEL ALI.A.# QUANTITY:·#SERVICE LINE ITEM-1: BEND TUBE REPLACEMENT INCLUDING BENDING &SWAGING OF TUBE AND COMPLETE REFRACTORY BOX CUTTING & REINS TATEMENT # 01QTY·#SERVICE LINE ITEM-2:	1	LS				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332500965
DATE : 18.04.2025
REQ No : 1032501844
REQ TITLE : PRJ-AUXB 60 tube leak rectifi
DELIVERY LOCATION
CLOSING DATE : 02.05.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>STRAIGHT TUBE REPLACEMENT # 01 QTY.#SERVICE LINE ITEM-3: ADDITIONAL BEND TUBE REPLACEMENT (IF REQUIREDBASED ON SITE FINDINGS) # 01 QTY.#SERVICE LINE ITEM-4: ADDITIONAL STRAIGHT TUBE REPLACEMENT (IFREQUIRED BASED ON SITE FINDI NGS) # 01 QTYNOTE: PAYMENT WILL BE MADE BASED ON THE ACTUAL QUANTITY OF WORK DONE ATTHE SITE ACCORDING TO THE TUBE LEAK LOCATION.B.# SPECIFICATION.#TUBE MATERIAL: SA210-A1 / SA210-C.#TUBE SIZE: 76.2MM X 3.6 MMC.#DURATION:.#FOR BEND TUBE REPLACEMENT INSIDE REFRACTOR Y BOX: 04 DAYS.#FOR STRAIGHT TUBE REPLACEMENT OUTSIDE REFRACTORY BOX: 02 DAYSD.#SCHEDULE.#WORK TO BE STARTED WITHIN 01 DAY OF ADVANC E NOTICE.E.#PRE-BID SITE INSPECTION:.#THE CONTRACTOR SHALL VISIT THE SITE AND MAKE THEMSELVES FULLYFAMILIAR WITH THE WORK SCOPE, PLA</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332500965
DATE : 18.04.2025
REQ No : 1032501844
REQ TITLE : PRJ-AUXB 60 tube leak rectifi
DELIVERY LOCATION
CLOSING DATE : 02.05.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>NT ACCESS, FACILITIES, COMPLEXITIES,ETC., BEFORE SUBMITTING THE BID. DEWA WILL NOT ACCEPT ANY CLAIM FOREXTRAS BEYOND THE ORDER RATES</p> <p>/ PRICES DURING AND AFTER THE EXECUTION OFWORK ORDERED.F.#QUALIFICATION OF BIDDER:.#THE BIDDER SHALL HAVE PROVEN EXPERIENCE FOR SIMILAR JOBS AND SHALLSUBMIT EVIDENCE.#THE BIDDER SHALL BE A VALID ASME #R# STAMP HOLDERG.#SCOPE OF WORK:1.#PREPARATION WORK1.#MOBILIZE MEN/EQUIPMENT WITHIN 01 DAY AFTER ORDER CONFIRMATION2.#WORK TO BE CARRIED OUT ROUND THE CLOCK IN DOUBLE SHIFTS.3.#OBTAIN PTW (PERMIT TO WORK) / LC (LINE CLEARANCE) FROM DEWA.4.#THE FOLLOWING DOCUMENTS ARE TO BE SUBMITTED TO OBTAIN PTW,4.1.#METHOD STATEMENT4.2.#RISK ASSESSMENT OF THE WORK4.3.#TOOLBOX TALK REPORT.5.#ENSURE PROPER ISOLATION OF THE LINE & VALID HWP IS AVAILABLE.6.#ENSURE</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332500965
DATE : 18.04.2025
REQ No : 1032501844
REQ TITLE : PRJ-AUXB 60 tube leak rectifi
DELIVERY LOCATION
CLOSING DATE : 02.05.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>NO FLAM MABLE MATERIALS NEAR THE HOT WORK AREA.7.#ENSURE THE AREA IS CORRECTLY SECURED AND SAFE TO WORK ON IN ALLRESPECTS.8.#CONDUCT SITE SU RVEY AND SAFETY INSPECTION TO ASSESS THE WORKINGENVIRONMENT.9.#IF THE WORKING ENVIRONMENT IS SAFE, YOU CAN PROCEED WITH THEFOLLOWING STEPS.II.#BEND TUBE REPLACEMENT AFTER CUTTING REFRACTORY BOX1.#REMOVE THE CLADDING SHEET & INSULATION.2.#CUT AND REMOVE THE WHOLE R EFRACTORY BOX.3.#REMOVE CASTABLE REFRACTORY AND REFRACTORY BRICKS.4.#IDENTIFY & MARK THE LEAKING TUBE ALONG WITH DEWA.5.#CUT THE TUB E FINS.6.#CUT THE FAILED TUBE.7.#COLLECT STRAIGHT TUBE FROM DEWA AND BEND IT AS PER OLD SAMPLE.8.#OPEN STEAM DRUM MANHOLE (DEWA SCOP E)9.#CUT & REMOVE BAFFLE PLATE IN THE STEAM DRUM AND PUNCH OUT THE</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332500965
DATE : 18.04.2025
REQ No : 1032501844
REQ TITLE : PRJ-AUXB 60 tube leak rectifi
DELIVERY LOCATION
CLOSING DATE : 02.05.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>FAILED TUBE.10.#TRANSPORT THE FAILED TUBE AND NEW TUBE FOR REPLACE MENT TO CONTRACTOR WORKSHOP.11.#BEND AND SWAGE THE NEW TUBE AS PER SAMPLE FAILED TUBE.12.#RETURN THE PREFABRICATED BEND TUBE.13.#PWHT AFTER TUBE SWAGING. (NDE WILL BE ARRANGED BY DEWA)14.#FIT UP THE PREFABRICATED BEND TUBE.15.#PREPARE FOR HALF SPLIT INSERT REPAIR MET HOD (WINDOW REPAIR) AND WELD THE TUBE.16.#RT OF THE WELDED JOINTS. (NDE WILL BE ARRANGED BY DEWA)17.#EXPAND TUBE TOP END INSIDE THE S TEAM DRUM.18.#REINSTALL THE REMOVED BAFFLE PLATES.19.#WELD THE FINS BACK IF THEY ARE REMOVED. (IF NEW PLATE REQUIRED FOR FINS, THEN T O BE SUPPLIED BY CONTRACTOR)20.#INSTALL BACK THE BRICKS.21.#INSTALL CASTABLE REFRACTORY (TO BE SUPPLIED BY CONTRACTOR AS PER EXISTING REFRACTORY SPECIFICATION).22.#REINSTATE</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332500965
DATE : 18.04.2025
REQ No : 1032501844
REQ TITLE : PRJ-AUXB 60 tube leak rectifi
DELIVERY LOCATION
CLOSING DATE : 02.05.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>THE REFRACTORY BOX WITH #V# TYPE EXPANSION FOLD,MATERIAL: ASTM A387 GRADE P22. (IF AN OLD B OX OR EXPANSION FOLD IS FOUND DAMAGED, THEN THE SAME IS TO BE REPLACED)23.#REINSTALL ROCKWOOL INSULATION, IF OLD INSULATION IS FOUND DAMAGED,THEN SAME TO BE REPLACED.24.#REINSTALL CLADDING SHEET, IF OLD SHEETS ARE FOUND DAMAGED, THENSAME TO BE REPLACED.25.#HYDROTES T AT SERVICE PRESSURE (DEWA SCOPE)III.#STRAIGHT TUBE REPLACEMENT1.#REMOVE THE CLADDING SHEET & INSULATION.2.#IDENTIFY & MARK THE LEA KING TUBE ALONG WITH DEWA3.#CUT THE TUBE FINS4.#CUT THE FAILED TUBE.5.#PREPARE FOR HALF SPLIT INSERT REPAIR METHOD (WINDOW REPAIR) A ND WELDTHE TUBE6.#RT OF THE WELDED JOINTS. (NDE WILL BE ARRANGED BY DEWA)7.#WELD THE FINS BACK.8.#REINSTALL ROCKWOOL INSULATION, IF</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332500965
DATE : 18.04.2025
REQ No : 1032501844
REQ TITLE : PRJ-AUXB 60 tube leak rectifi
DELIVERY LOCATION
CLOSING DATE : 02.05.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>OLD INSULATION IS FOUND DAMAGED, THEN SAME TO BE REPLACED.9.#REINSTALL CLADDING SHEET, IF OLD SHEETS ARE FOUND DAMAGED, THEN SAMETO B</p> <p>E REPLACED.10.#HYDROTEST AT SERVICE PRESSURE (DEWA SCOPE)IV.#GENERAL CONDITIONS1.#A QUALIFIED JOB SUPERVISOR SHALL BE ASSIGNED FOR T</p> <p>HE JOB.2.#QUALIFIED & SKILLED FABRICATORS/ MASONS TO CARRY OUT ALL THE</p> <p>JOBS.3.#HOUSEKEEPING AND DISPOSAL OF WASTE SHALL BE DONE AS P</p> <p>ER DEWA RULESON A DAILY BASIS.4.#HAZARDOUS & NON-HAZARDOUS TO BE SEPARATED BEFORE DISPOSAL.5.#DE-MOBILIZE MEN AND EQUIPMENT AFTER CO</p> <p>MPLETION OF THE JOB.6.#COMPLETION REPORT WITH PHOTOS TO BE SUBMITTED TO DEWA WITHIN 02 DAYS AFTER JOB COMPLETION.7.#ALL TOOLS & TACKL</p> <p>ES ARE IN THE CONTRACTOR#S SCOPE.8.#VALID TEST CERTIFICATES OF ALL LIFTING TOOLS, ELECTRICALTOOLS/CABLES, AND GAS</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332500965
DATE : 18.04.2025
REQ No : 1032501844
REQ TITLE : PRJ-AUXB 60 tube leak rectifi
DELIVERY LOCATION
CLOSING DATE : 02.05.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>CYLINDERS/HOSES TO BE SUBMITTED BEFORE START OF WORK.9.#VALID CALIBRATION CERTIFICATE OF THE WELDING MACHINES TO BE SUBMITTED BEFORE WORK STARTS.10.#WPS , PQR & WELDER QUALIFICATION CERTIFICATES TO BE SUBMITTED BEFORE THE START OF WORK.11.#ALL WELDING IS TO BE CARRIED OUT BY QUALIFIED WELDER AND AS PER WPS IN ACCORDANCE WITH REQUIREMENTS OF ASME CODE.12.#DEWA# SCOPE: -12.1.#INSTALLATION OF SCAFFOLDING12.2.#SUPPLY OF ASTM A387 GRADE P22 PLATE (IF REQUIRED)12.3.#SPARE TUBE FOR REPLACEMENT12.4.#NDE12.5.#ROCKWOOL & CLADDING SHEET, IF REQUIRED.12.6.# DRUM MANHOLE OPENING & CLOSING, IF REQUIRED.12.7.#PWHT OF THE TUBE AFTER SWAGING.H.#WARRANTY.#THE WARRANTY PERIOD FOR THE WORK SHALL BE 01 YEAR FROM THE DATE OF COMPLETION OF WORK CERTIFIED BY DEWA.#IN CASE OF ANY</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332500965
DATE : 18.04.2025
REQ No : 1032501844
REQ TITLE : PRJ-AUXB 60 tube leak rectifi
DELIVERY LOCATION
CLOSING DATE : 02.05.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>DAMAGE/DEFECT OF THE WORK CARRIED OUT UNDER THISCO</p> <p>NTRACT WITHIN THIS WARRANTY PERIOD, THE CONTRACTOR SHALL ATTEND ANDCARRY OUT THE NECESSARY REPAIR WORK AND RECTIFY THE DEFECT WITHIN</p> <p>ASHORT PERIOD.I.#GENERAL TERMS & CONDITIONS.#CONTRACTOR SHALL HAVE PREVIOUS WORK EXPERIENCE FOR THE SIMILAR JOB.#CONTRACTOR SHALL S</p> <p>UBMIT METHOD OF STATEMENT AND SCHEDULE UPON ORDERCONFIRMATION.#ALL</p> <p>TRANSPORTING AND REQUIRED EQUIPMENT SHOULD BE ARRANGED BY THECON</p> <p>TRACTOR. THIS EQUIPMENT SHOULD BE DULY TESTED AND CERTIFIED BY THE3RD PARTY INSPECTION AGENCY AND THE CERTIFICATES SHOULD BE PRODUCE</p> <p>D ONDEMAND. QUALIFIED MECHANICS SHOULD BE PROVIDED.#THE CONTRACTOR SHALL VISIT THE SITE AND MAKE HIMSELF FULLY FAMILIARWITH THE WOR</p> <p>K SCOPE, PLANT ACCESS, FACILITIES,</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332500965
DATE : 18.04.2025
REQ No : 1032501844
REQ TITLE : PRJ-AUXB 60 tube leak rectifi
DELIVERY LOCATION
CLOSING DATE : 02.05.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>COMPLEXITIES, SAFETY MEASURES ETC., BEFORE HE SUBMITS HIS BID. #THE CONTRACTOR SHALL ENSURE HOUSEKEEPING ON A DAILY BASIS AND THE CONTRACTOR SHALL BE RESPONSIBLE FOR ALL WASTE MATERIAL DISPOSAL TO DESIGNATED PLACES. #ALL DEWA SAFETY & ENVIRONMENT POLICY, RULES AND REGULATIONS SHALL BE FOLLOWED AT THE WORK SITE DURING THE EXECUTION OF THE WORK. THE CONTRACTOR'S ENGINEER SHOULD BE FAMILIAR WITH SAFETY REGULATIONS WHILE WORKING IN A HAZARDOUS AREA. #SCAFFOLDING IF REQUIRED SHALL BE ARRANGED BY DEW</p> <p>A. #THE WORK SHALL BE EXECUTED UNDER DEWA SUPERVISION AND AS PER QUALITY/SCHEDULE REQUIREMENT. #THE CONTRACTOR'S SUPERVISOR SHALL BE AVAILABLE AT SITE THROUGHOUT THE PERIOD OF WORK. #DEWA WILL ARRANGE NECESSARY PTW / LC / HWP FROM OPERATION, CHEMICAL LAB / FIRE DEPAR</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332500965
DATE : 18.04.2025
REQ No : 1032501844
REQ TITLE : PRJ-AUXB 60 tube leak rectifi
DELIVERY LOCATION
CLOSING DATE : 02.05.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>TMENT CLEARANCES TO CARRY OUT THE SCOPE OF WORK UNDER THIS CONTRACT. #THE CONTRACTOR UPON RECEIVING THE WORK PERMIT SHALL FIRST ENSURE A SAFE WORKING CONDITION. #ALL THE PERSONS SHOULD WEAR ALL THE REQUIRED PPE WHILE AT WORK. #ALL MATERIAL AND TOOLS BROUGHT IN SHALL BE DECLARED AT THE POWERSTATION SECURITY GATE AND THE LIST OF THESE ITEMS SHALL BE SIGNED BY DEWA SECURITY. THE COPIES OF THESE DOCUMENTS SHALL BE LODGED WITH THE DEWA ENGINEER IN CHARGE ON DAILY BASIS. THIS DOCUMENT WILL BE THE BASIS FOR THE CLEARANCE (GATE PASS) TO TAKE THEM OUT ON COMPLETION OF THE JOB. SERVICE AIR, ELECTRICITY AND WATER</p>						
3		ITEM-00001	<p>DHGT251659264 FLAYOUT IN CELL 1 FOLLOW OVERLAP 1 BEHIND DOCUMENT 0 F HIDDEN 0 FLAYOUT IN CELL 1 DEWA-CONFIDENTIAL DHGT251660288 FLAYOUT IN CELL 1 FOLLOW OVER</p>	1	LS				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332500965
DATE : 18.04.2025
REQ No : 1032501844
REQ TITLE : PRJ-AUXB 60 tube leak rectifi
DELIVERY LOCATION
CLOSING DATE : 02.05.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>RLAP1FBEHINDDOCUMENT0FHIDDEN0FLAYOUTINC ELL1DEWA-CONFIDENTIALTITLE: AUXB 60 TUBE LEAK RECTIFICATION AT M STATION, DEWA, JEBEL ALI.A.# QUANTITY:·#SERVICE LINE ITEM-1: BEND TUBE REPLACEMENT INCLUDING BENDING &SWAGING OF TUBE AND COMPLETE REFRACTORY BOX CUTTING & REINS TATEMENT # 01QTY·#SERVICE LINE ITEM-2: STRAIGHT TUBE REPLACEMENT # 01 QTY·#SERVICE LINE ITEM-3: ADDITIONAL BEND TUBE REPLACEMENT (IF REQUIREDBASED ON SITE FINDINGS) # 01 QTY·#SERVICE LINE ITEM-4: ADDITIONAL STRAIGHT TUBE REPLACEMENT (IFREQUIRED BASED ON SITE FINDI NGS) # 01 QTYNOTE: PAYMENT WILL BE MADE BASED ON THE ACTUAL QUANTITY OF WORK DONE ATTHE SITE ACCORDING TO THE TUBE LEAK LOCATION.B.# SPECIFICATION·#TUBE MATERIAL: SA210-A1 / SA210-C·#TUBE SIZE: 76.2MM X 3.6 MMC·#DURATION:·#FOR BEND TUBE</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332500965
DATE : 18.04.2025
REQ No : 1032501844
REQ TITLE : PRJ-AUXB 60 tube leak rectifi
DELIVERY LOCATION
CLOSING DATE : 02.05.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			REPLACEMENT INSIDE REFRACTOR Y BOX: 04 DAYS.#FOR STRAIGHT TUBE REPLACEMENT OUTSIDE REFRACTORY BOX: 02 DAYSD.#SCHEDULE.#WORK TO BE STARTED WITHIN 01 DAY OF ADVANC E NOTICE.E.#PRE-BID SITE INSPECTION:.#THE CONTRACTOR SHALL VISIT THE SITE AND MAKE THEMSELVES FULLYFAMILIAR WITH THE WORK SCOPE, PLA NT ACCESS, FACILITIES, COMPLEXITIES,ETC., BEFORE SUBMITTING THE BID. DEWA WILL NOT ACCEPT ANY CLAIM FOREXTRAS BEYOND THE ORDER RATES / PRICES DURING AND AFTER THE EXECUTION OFWORK ORDERED.F.#QUALIFICATION OF BIDDER:.#THE BIDDER SHALL HAVE PROVEN EXPERIENCE FOR SIM ILAR JOBS AND SHALLSUBMIT EVIDENCE.#THE BIDDER SHALL BE A VALID ASME #R# STAMP HOLDERG.#SCOPE OF WORK:I.#PREPARATION WORK1.#MOBILIZ E MEN/EQUIPMENT WITHIN 01 DAY AFTER ORDER CONFIRMATION2.#WORK TO BE CARRIED OUT						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332500965
DATE : 18.04.2025
REQ No : 1032501844
REQ TITLE : PRJ-AUXB 60 tube leak rectifi
DELIVERY LOCATION
CLOSING DATE : 02.05.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>ROUND THE CLOCK IN DOUBLE SHIFTS.3.#OBTAIN PTW (PERM IT TO WORK) / LC (LINE CLEARANCE) FROM DEWA.4.#THE FOLLOWING DOCUMENTS ARE TO BE SUBMITTED TO OBTAIN PTW,4.1.#METHOD STATEMENT4.2.#RISK ASSESSMENT OF THE WORK4.3.#TOOLBOX TALK REPORT.5.#ENSURE PROPER ISOLATION OF THE LINE & VALID HWP IS AVAILABLE.6.#ENSURE NO FLAMMABLE MATERIALS NEAR THE HOT WORK AREA.7.#ENSURE THE AREA IS CORRECTLY SECURED AND SAFE TO WORK ON IN ALLRESPECTS.8.#CONDUCT SITE SURVEY AND SAFETY INSPECTION TO ASSESS THE WORKINGENVIRONMENT.9.#IF THE WORKING ENVIRONMENT IS SAFE, YOU CAN PROCEED WITH THEFOLLOWING STEPS.II.#BEND TUBE REPLACEMENT AFTER CUTTING REFRACTORY BOX1.#REMOVE THE CLADDING SHEET & INSULATION.2.#CUT AND REMOVE THE WHOLE REFRACTORY BOX.3.#REMOVE CASTABLE</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332500965
DATE : 18.04.2025
REQ No : 1032501844
REQ TITLE : PRJ-AUXB 60 tube leak rectifi
DELIVERY LOCATION
CLOSING DATE : 02.05.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			REFRACTORY AND REFRACTORY BRICKS.4.#IDENTIFY & MARK THE LEAKING TUBE ALONG WITH DEWA.5.#CUT THE TUB E FINS.6.#CUT THE FAILED TUBE.7.#COLLECT STRAIGHT TUBE FROM DEWA AND BEND IT AS PER OLD SAMPLE.8.#OPEN STEAM DRUM MANHOLE (DEWA SCOP E)9.#CUT & REMOVE BAFFLE PLATE IN THE STEAM DRUM AND PUNCH OUT THE FAILED TUBE.10.#TRANSPORT THE FAILED TUBE AND NEW TUBE FOR REPLACE MENT TO CONTRACTOR WORKSHOP.11.#BEND AND SWAGE THE NEW TUBE AS PER SAMPLE FAILED TUBE.12.#RETURN THE PREFABRICATED BEND TUBE.13.#PWHT AFTER TUBE SWAGING. (NDE WILL BE ARRANGED BY DEWA)14.#FIT UP THE PREFABRICATED BEND TUBE.15.#PREPARE FOR HALF SPLIT INSERT REPAIR MET HOD (WINDOW REPAIR) AND WELD THE TUBE.16.#RT OF THE WELDED JOINTS. (NDE WILL BE ARRANGED BY DEWA)17.#EXPAND TUBE TOP END INSIDE THE S						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332500965
DATE : 18.04.2025
REQ No : 1032501844
REQ TITLE : PRJ-AUXB 60 tube leak rectifi
DELIVERY LOCATION
CLOSING DATE : 02.05.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			TEAM DRUM.18.#REINSTALL THE REMOVED BAFFLE PLATES.19.#WELD THE FINS BACK IF THEY ARE REMOVED. (IF NEW PLATE REQUIRED FORFINS, THEN T O BE SUPPLIED BY CONTRACTOR)20.#INSTALL BACK THE BRICKS.21.#INSTALL CASTABLE REFRACTORY (TO BE SUPPLIED BY CONTRACTOR AS PEREXISTING REFRACTORY SPECIFICATION).22.#REINSTATE THE REFRACTORY BOX WITH #V# TYPE EXPANSION FOLD,MATERIAL: ASTM A387 GRADE P22. (IF AN OLD B OX OR EXPANSION FOLD IS FOUNDDAMAGED, THEN THE SAME IS TO BE REPLACED)23.#REINSTALL ROCKWOOL INSULATION, IF OLD INSULATION IS FOUND DAMAGED,THEN SAME TO BE REPLACED.24.#REINSTALL CLADDING SHEET, IF OLD SHEETS ARE FOUND DAMAGED, THENSAME TO BE REPLACED.25.#HYDROTES T AT SERVICE PRESSURE (DEWA SCOPE)III.#STRAIGHT TUBE REPLACEMENT1.#REMOVE THE CLADDING SHEET						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332500965
DATE : 18.04.2025
REQ No : 1032501844
REQ TITLE : PRJ-AUXB 60 tube leak rectifi
DELIVERY LOCATION
CLOSING DATE : 02.05.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>& INSULATION.2.#IDENTIFY & MARK THE LEAKING TUBE ALONG WITH DEWA3.#CUT THE TUBE FINS4.#CUT THE FAILED TUBE.5.#PREPARE FOR HALF SPLIT INSERT REPAIR METHOD (WINDOW REPAIR) A</p> <p>ND WELD THE TUBE6.#RT OF THE WELDED JOINTS. (NDE WILL BE ARRANGED BY DEWA)7.#WELD THE FINS BACK.8.#REINSTALL ROCKWOOL INSULATION, IF</p> <p>OLD INSULATION IS FOUND DAMAGED, THEN SAME TO BE REPLACED.9.#REINSTALL CLADDING SHEET, IF OLD SHEETS ARE FOUND DAMAGED, THEN SAME TO B</p> <p>E REPLACED.10.#HYDROTEST AT SERVICE PRESSURE (DEWA SCOPE)IV.#GENERAL CONDITIONS1.#A QUALIFIED JOB SUPERVISOR SHALL BE ASSIGNED FOR THE JOB.2.#QUALIFIED & SKILLED FABRICATORS/ MASONS TO CARRY OUT ALL THE JOBS.3.#HOUSEKEEPING AND DISPOSAL OF WASTE SHALL BE DONE AS PER DEWA RULESON A DAILY BASIS.4.#HAZARDOUS & NON-HAZARDOUS TO BE SEPARATED BEFORE</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332500965
DATE : 18.04.2025
REQ No : 1032501844
REQ TITLE : PRJ-AUXB 60 tube leak rectifi
DELIVERY LOCATION
CLOSING DATE : 02.05.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			DISPOSAL.5.#DE-MOBILIZE MEN AND EQUIPMENT AFTER COMPLETION OF THE JOB.6.#COMPLETION REPORT WITH PHOTOS TO BE SUBMITTED TO DEWA WITHIN 02 DAYS AFTER JOB COMPLETION.7.#ALL TOOLS & TACKLES ARE IN THE CONTRACTOR#S SCOPE.8.#VALID TEST CERTIFICATES OF ALL LIFTING TOOLS, ELECTRICAL TOOLS/CABLES, AND GAS CYLINDERS/HOSES TO BE SUBMITTED BEFORE START OF WORK.9.#VALID CALIBRATION CERTIFICATE OF THE WELDING MACHINES TO BE SUBMITTED BEFORE WORK STARTS.10.#WPS , PQR & WELDER QUALIFICATION CERTIFICATES TO BE SUBMITTED BEFORE THE START OF WORK.11.#ALL WELDING IS TO BE CARRIED OUT BY QUALIFIED WELDER AND AS PER WPS IN ACCORDANCE WITH REQUIREMENTS OF ASME CODE.12.#DEWA# SCOPE: -12.1.#INSTALLATION OF SCAFFOLDING12.2.#SUPPLY OF ASTM A387 GRADE P22 PLATE (IF						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332500965
DATE : 18.04.2025
REQ No : 1032501844
REQ TITLE : PRJ-AUXB 60 tube leak rectifi
DELIVERY LOCATION
CLOSING DATE : 02.05.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>REQUIRED)12.3.#SPARE TUBE FOR REPLACEMENT12.4.#NDE12.5.#ROCKWOOL & CLADDING SHEET, IF REQUIRED.12.6.# DRUM MANHOLE OPENING & CLOSING, IF REQUIRED.12.7.#PWHT OF THE TUBE AFTER SWAGING.H.#WARRANTY.#THE WARRANTY PERIOD FOR THE WORK SHALL BE 01 YEAR FROM THE DATE OFCOMPLETION OF WORK CERTIFIED BY DEWA.#IN CASE OF ANY DAMAGE/DEFECT OF THE WORK CARRIED OUT UNDER THISCO NTRACT WITHIN THIS WARRANTY PERIOD, THE CONTRACTOR SHALL ATTEND ANDCARRY OUT THE NECESSARY REPAIR WORK AND RECTIFY THE DEFECT WITHIN ASHORT PERIOD.I.#GENERAL TERMS & CONDITIONS.#CONTRACTOR SHALL HAVE PREVIOUS WORK EXPERIENCE FOR THE SIMILAR JOB.#CONTRACTOR SHALL S UBMIT METHOD OF STATEMENT AND SCHEDULE UPON ORDERCONFIRMATION.#ALL TRANSPORTING AND REQUIRED EQUIPMENT SHOULD BE ARRANGED BY THECON</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332500965
DATE : 18.04.2025
REQ No : 1032501844
REQ TITLE : PRJ-AUXB 60 tube leak rectifi
DELIVERY LOCATION
CLOSING DATE : 02.05.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>TRACTOR. THIS EQUIPMENT SHOULD BE DULY TESTED AND CERTIFIED BY THE 3RD PARTY INSPECTION AGENCY AND THE CERTIFICATES SHOULD BE PRODUCED ON DEMAND. QUALIFIED MECHANICS SHOULD BE PROVIDED. #THE CONTRACTOR SHALL VISIT THE SITE AND MAKE HIMSELF FULLY FAMILIAR WITH THE WORK SCOPE, PLANT ACCESS, FACILITIES, COMPLEXITIES, SAFETY MEASURES ETC., BEFORE HE SUBMITS HIS BID. #THE CONTRACTOR SHALL ENSURE HOUSEKEEPING ON A DAILY BASIS AND THE CONTRACTOR SHALL BE RESPONSIBLE FOR ALL WASTE MATERIAL DISPOSAL TO DESIGNATED PLACES. #ALL DEWA SAFETY & ENVIRONMENT POLICY, RULES AND REGULATIONS SHALL BE FOLLOWED AT THE WORK SITE DURING THE EXECUTION OF THE WORK. THE CONTRACTOR'S ENGINEER SHOULD BE FAMILIAR WITH SAFETY REGULATIONS WHILE WORKING IN A HAZARDOUS AREA. #SCAFFOLDING IF REQUIRED SHALL BE</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332500965
DATE : 18.04.2025
REQ No : 1032501844
REQ TITLE : PRJ-AUXB 60 tube leak rectifi
DELIVERY LOCATION
CLOSING DATE : 02.05.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>ARRANGED BY DEW</p> <p>A.#THE WORK SHALL BE EXECUTED UNDER DEWA SUPERVISION AND AS PERQUALITY/SCHEDULE REQUIREMENT.#THE CONTRACTOR#S SUPERVISOR SHALL BE AVAILABLE AT SITE THROUGHOUT THEPERIOD OF WORK.#DEWA WILL ARRANGE NECESSARY PTW / LC / HWP FROM OPERATION, CHEMICALLAB / FIRE DEPAR</p> <p>TMENT CLEARANCES TO CARRY OUT THE SCOPE OF WORK UNDERTHIS CONTRACT.#THE CONTRACTOR UPON RECEIVING THE WORK PERMIT SHALL FIRST ENSUR</p> <p>E ASAFE WORKING CONDITION.#ALL THE PERSONS SHOULD WEAR ALL THE REQUIRED PPE WHILE AT WORK.#ALL MATERIAL AND TOOLS BROUGHT IN SHALL</p> <p>BE DECLARED AT THE POWERSTATION SECURITY GATE AND THE LIST OF THESE ITEMS SHALL BE SIGNED BYDEWA SECURITY. THE COPIES OF THESE DOCU</p> <p>MENTS SHALL BE LODGED WITH THEDEWA ENGINEER IN CHARGE ON DAILY BASIS. THIS</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332500965
DATE : 18.04.2025
REQ No : 1032501844
REQ TITLE : PRJ-AUXB 60 tube leak rectifi
DELIVERY LOCATION
CLOSING DATE : 02.05.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			DOCUMENT WILL BE THE BASISFOR THE CLEARANCE (GATE PASS) T O TAKE THEM OUT ON COMPLETION OF THE JOB.SERVICE AIR, ELECTRICITY AND WAT						
4		ITEM-00001	DHGT251659264FLAYOUTINCELL1FALLOWOVERLAP 1FBEHINDDOCUMENT0FHIDDEN0FLAYOUTINCELL1 DEWA- CONFIDENTIALDHGT251660288FLAYOUTINCELL1FA LLOWOVE RLAP1FBEHINDDOCUMENT0FHIDDEN0FLAYOUTINC ELL1DEWA-CONFIDENTIALTITLE: AUXB 60 TUBE LEAK RECTIFICATION AT M STATION, DEWA, JEBEL ALI.A.# QUANTITY:#SERVICE LINE ITEM-1: BEND TUBE REPLACEMENT INCLUDING BENDING &SWAGING OF TUBE AND COMPLETE REFRACTORY BOX CUTTING & REINS TATEMENT # 01QTY:#SERVICE LINE ITEM-2: STRAIGHT TUBE REPLACEMENT # 01 QTY:#SERVICE LINE ITEM-3: ADDITIONAL BEND TUBE REPLACEMENT (IF REQUIREDBASED ON SITE FINDINGS) # 01 QTY:#SERVICE LINE ITEM-4: ADDITIONAL STRAIGHT	1	LS				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332500965
DATE : 18.04.2025
REQ No : 1032501844
REQ TITLE : PRJ-AUXB 60 tube leak rectifi
DELIVERY LOCATION
CLOSING DATE : 02.05.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>TUBE REPLACEMENT (IF REQUIRED BASED ON SITE FINDI NGS) # 01 QTYNOTE: PAYMENT WILL BE MADE BASED ON THE ACTUAL QUANTITY OF WORK DONE AT THE SITE ACCORDING TO THE TUBE LEAK LOCATION.B.# SPECIFICATION.#TUBE MATERIAL: SA210-A1 / SA210-C.#TUBE SIZE: 76.2MM X 3.6 MMC.#DURATION:.#FOR BEND TUBE REPLACEMENT INSIDE REFRACTOR Y BOX: 04 DAYS.#FOR STRAIGHT TUBE REPLACEMENT OUTSIDE REFRACTORY BOX: 02 DAYS.#SCHEDULE.#WORK TO BE STARTED WITHIN 01 DAY OF ADVANC E NOTICE.E.#PRE-BID SITE INSPECTION:.#THE CONTRACTOR SHALL VISIT THE SITE AND MAKE THEMSELVES FULLY FAMILIAR WITH THE WORK SCOPE, PLA NT ACCESS, FACILITIES, COMPLEXITIES, ETC., BEFORE SUBMITTING THE BID. DEWA WILL NOT ACCEPT ANY CLAIM FOR EXTRAS BEYOND THE ORDER RATES / PRICES DURING AND AFTER THE EXECUTION</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332500965
DATE : 18.04.2025
REQ No : 1032501844
REQ TITLE : PRJ-AUXB 60 tube leak rectifi
DELIVERY LOCATION
CLOSING DATE : 02.05.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>OFWORK ORDERED.F.#QUALIFICATION OF BIDDER:.#THE BIDDER SHALL HAVE PROVEN EXPERIENCE FOR SIMILAR JOBS AND SHALLSUBMIT EVIDENCE. #THE BIDDER SHALL BE A VALID ASME #R# STAMP HOLDERG.#SCOPE OF WORK:I.#PREPARATION WORK1.#MOBILIZE MEN/EQUIPMENT WITHIN 01 DAY AFTER ORDER CONFIRMATION2.#WORK TO BE CARRIED OUT ROUND THE CLOCK IN DOUBLE SHIFTS.3.#OBTAIN PTW (PERMIT TO WORK) / LC (LINE CLEARANCE) FROM DEWA.4.#THE FOLLOWING DOCUMENTS ARE TO BE SUBMITTED TO OBTAIN PTW,4.1.#METHOD STATEMENT4.2.#RISK ASSESSMENT OF THE WORK4.3.#TOOLBOX TALK REPORT.5.#ENSURE PROPER ISOLATION OF THE LINE & VALID HWP IS AVAILABLE.6.#ENSURE NO FLAMMABLE MATERIALS NEAR THE HOT WORK AREA.7.#ENSURE THE AREA IS CORRECTLY SECURED AND SAFE TO WORK ON IN ALLRESPECTS.8.#CONDUCT SITE SU</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332500965
DATE : 18.04.2025
REQ No : 1032501844
REQ TITLE : PRJ-AUXB 60 tube leak rectifi
DELIVERY LOCATION
CLOSING DATE : 02.05.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>RVEY AND SAFETY INSPECTION TO ASSESS THE WORKINGENVIRONMENT.9.#IF THE WORKING ENVIRONMENT IS SAFE, YOU CAN PROCEED WITH THEFOLLOWING STEPS.II.#BEND TUBE REPLACEMENT AFTER CUTTING REFRACTORY BOX1.#REMOVE THE CLADDING SHEET & INSULATION.2.#CUT AND REMOVE THE WHOLE R EFRACTORY BOX.3.#REMOVE CASTABLE REFRACTORY AND REFRACTORY BRICKS.4.#IDENTIFY & MARK THE LEAKING TUBE ALONG WITH DEWA.5.#CUT THE TUB E FINS.6.#CUT THE FAILED TUBE.7.#COLLECT STRAIGHT TUBE FROM DEWA AND BEND IT AS PER OLD SAMPLE.8.#OPEN STEAM DRUM MANHOLE (DEWA SCOP E)9.#CUT & REMOVE BAFFLE PLATE IN THE STEAM DRUM AND PUNCH OUT THE FAILEDTUBE.10.#TRANSPORT THE FAILED TUBE AND NEW TUBE FOR REPLACE MENT TOCONTRACTOR WORKSHOP.11.#BEND AND SWAGE THE NEW TUBE AS PER SAMPLE FAILED TUBE.12.#RETURN THE PREFABRICATED BEND</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332500965
DATE : 18.04.2025
REQ No : 1032501844
REQ TITLE : PRJ-AUXB 60 tube leak rectifi
DELIVERY LOCATION
CLOSING DATE : 02.05.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>TUBE13.#PWHT AFTER TUBE SWAGING. (NDE WILL BE ARRANGED BY DEWA)14.#FIT UP THE PREFABRICATED BEND TUBE15.#PREPARE FOR HALF SPLIT INSERT REPAIR MET HOD (WINDOW REPAIR) ANDWELD THE TUBE.16.#RT OF THE WELDED JOINTS. (NDE WILL BE ARRANGED BY DEWA)17.#EXPAND TUBE TOP END INSIDE THE S TEAM DRUM.18.#REINSTALL THE REMOVED BAFFLE PLATES.19.#WELD THE FINS BACK IF THEY ARE REMOVED. (IF NEW PLATE REQUIRED FORFINS, THEN T O BE SUPPLIED BY CONTRACTOR)20.#INSTALL BACK THE BRICKS.21.#INSTALL CASTABLE REFRACTORY (TO BE SUPPLIED BY CONTRACTOR AS PEREXISTING REFRACTORY SPECIFICATION).22.#REINSTATE THE REFRACTORY BOX WITH #V# TYPE EXPANSION FOLD,MATERIAL: ASTM A387 GRADE P22. (IF AN OLD B OX OR EXPANSION FOLD IS FOUND DAMAGED, THEN THE SAME IS TO BE</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332500965
DATE : 18.04.2025
REQ No : 1032501844
REQ TITLE : PRJ-AUXB 60 tube leak rectifi
DELIVERY LOCATION
CLOSING DATE : 02.05.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			REPLACED)23.#REINSTALL ROCKWOOL INSULATION, IF OLD INSULATION IS FOUND DAMAGED,THEN SAME TO BE REPLACED.24.#REINSTALL CLADDING SHEET, IF OLD SHEETS ARE FOUND DAMAGED, THENSAME TO BE REPLACED.25.#HYDROTES T AT SERVICE PRESSURE (DEWA SCOPE)III.#STRAIGHT TUBE REPLACEMENT1.#REMOVE THE CLADDING SHEET & INSULATION.2.#IDENTIFY & MARK THE LEAKING TUBE ALONG WITH DEWA3.#CUT THE TUBE FINS4.#CUT THE FAILED TUBE.5.#PREPARE FOR HALF SPLIT INSERT REPAIR METHOD (WINDOW REPAIR) A ND WELDTHE TUBE6.#RT OF THE WELDED JOINTS. (NDE WILL BE ARRANGED BY DEWA)7.#WELD THE FINS BACK.8.#REINSTALL ROCKWOOL INSULATION, IF OLD INSULATION IS FOUND DAMAGED,THEN SAME TO BE REPLACED.9.#REINSTALL CLADDING SHEET, IF OLD SHEETS ARE FOUND DAMAGED, THEN SAMETO B E REPLACED.10.#HYDROTEST AT SERVICE						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332500965
DATE : 18.04.2025
REQ No : 1032501844
REQ TITLE : PRJ-AUXB 60 tube leak rectifi
DELIVERY LOCATION
CLOSING DATE : 02.05.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>PRESSURE (DEWA SCOPE)IV.#GENERAL CONDITIONS1.#A QUALIFIED JOB SUPERVISOR SHALL BE ASSIGNED FOR THE JOB.2.#QUALIFIED & SKILLED FABRICATORS/ MASONS TO CARRY OUT ALL THE JOBS.3.#HOUSEKEEPING AND DISPOSAL OF WASTE SHALL BE DONE AS PER DEWA RULESON A DAILY BASIS.4.#HAZARDOUS & NON-HAZARDOUS TO BE SEPARATED BEFORE DISPOSAL.5.#DE-MOBILIZE MEN AND EQUIPMENT AFTER COMPLETION OF THE JOB.6.#COMPLETION REPORT WITH PHOTOS TO BE SUBMITTED TO DEWA WITHIN 02 DAYS AFTER JOB COMPLETION.7.#ALL TOOLS & TACKLES ARE IN THE CONTRACTOR'S SCOPE.8.#VALID TEST CERTIFICATES OF ALL LIFTING TOOLS, ELECTRICAL TOOLS/CABLES, AND GAS CYLINDERS/HOSES TO BE SUBMITTED BEFORE START OF WORK.9.#VALID CALIBRATION CERTIFICATE OF THE WELDING MACHINES TO BE SUBMITTED BEFORE WORK STARTS.10.#WPS</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332500965
DATE : 18.04.2025
REQ No : 1032501844
REQ TITLE : PRJ-AUXB 60 tube leak rectifi
DELIVERY LOCATION
CLOSING DATE : 02.05.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>, PQR & WELDER QUALIFICATION CERTIFICATES TO BE SUBMITTED BEFORE THE START OF WORK.11.#ALL WELDING IS TO BE CARRIED OUT BY QUALIFIED WELDER AND AS PER WPS IN ACCORDANCE WITH REQUIREMENTS OF ASME CODE.12.#DEWA# SCOPE: -12.1.#INSTALLATION OF SCAFFOLDING12.2.#SUPPLY OF ASTM A387 GRADE P22 PLATE (IF REQUIRED)12.3.#SPARE TUBE FOR REPLACEMENT12.4.#NDE12.5.#ROCKWOOL & CLADDING SHEET, IF REQUIRED.12.6.# DRUM MANHOLE OPENING & CLOSING, IF REQUIRED.12.7.#PWHT OF THE TUBE AFTER SWAGING.H.#WARRANTY.#THE WARRANTY PERIOD FOR THE WORK SHALL BE 01 YEAR FROM THE DATE OF COMPLETION OF WORK CERTIFIED BY DEWA.#IN CASE OF ANY DAMAGE/DEFECT OF THE WORK CARRIED OUT UNDER THIS CONTRACT WITHIN THIS WARRANTY PERIOD, THE CONTRACTOR SHALL ATTEND AND CARRY OUT THE NECESSARY REPAIR WORK AND RECTIFY THE</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332500965
DATE : 18.04.2025
REQ No : 1032501844
REQ TITLE : PRJ-AUXB 60 tube leak rectifi
DELIVERY LOCATION
CLOSING DATE : 02.05.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>DEFECT WITHIN ASHORT PERIOD.I.#GENERAL TERMS & CONDITIONS.#CONTRACTOR SHALL HAVE PREVIOUS WORK EXPERIENCE FOR THE SIMILAR JOB.#CONTRACTOR SHALL S UBMIT METHOD OF STATEMENT AND SCHEDULE UPON ORDERCONFIRMATION.#ALL TRANSPORTING AND REQUIRED EQUIPMENT SHOULD BE ARRANGED BY THECON TRACTOR. THIS EQUIPMENT SHOULD BE DULY TESTED AND CERTIFIED BY THE3RD PARTY INSPECTION AGENCY AND THE CERTIFICATES SHOULD BE PRODUCE D ONDEMAND. QUALIFIED MECHANICS SHOULD BE PROVIDED.#THE CONTRACTOR SHALL VISIT THE SITE AND MAKE HIMSELF FULLY FAMILIARWITH THE WOR K SCOPE, PLANT ACCESS, FACILITIES, COMPLEXITIES, SAFETYMEASURES ETC., BEFORE HE SUBMITS HIS BID.#THE CONTRACTOR SHALL ENSURE HOUSEK EEPING ON A DAILY BASIS AND THECONTRACTOR SHALL BE RESPONSIBLE FOR ALL WASTE</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332500965
DATE : 18.04.2025
REQ No : 1032501844
REQ TITLE : PRJ-AUXB 60 tube leak rectifi
DELIVERY LOCATION
CLOSING DATE : 02.05.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>MATERIAL DISPOSAL TO DESIGNATED PLACES. #ALL DEWA SAFETY & ENVIRONMENT POLICY, RULES AND REGULATIONS SHALL BE FOLLOWED AT THE WORK SITE DURING THE EXECUTION OF THE WORK. THE CONTRACTOR'S ENGINEER SHOULD BE FAMILIAR WITH SAFETY REGULATIONS WHILE WORKING IN A HAZARDOUS AREA. #SCAFFOLDING IF REQUIRED SHALL BE ARRANGED BY DEW</p> <p>A. #THE WORK SHALL BE EXECUTED UNDER DEWA SUPERVISION AND AS PER QUALITY/SCHEDULE REQUIREMENT. #THE CONTRACTOR'S SUPERVISOR SHALL BE AVAILABLE AT SITE THROUGHOUT THE PERIOD OF WORK. #DEWA WILL ARRANGE NECESSARY PTW / LC / HWP FROM OPERATION, CHEMICAL LAB / FIRE DEPARTMENT CLEARANCES TO CARRY OUT THE SCOPE OF WORK UNDER THIS CONTRACT. #THE CONTRACTOR UPON RECEIVING THE WORK PERMIT SHALL FIRST ENSURE A SAFE WORKING CONDITION. #ALL THE</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332500965
DATE : 18.04.2025
REQ No : 1032501844
REQ TITLE : PRJ-AUXB 60 tube leak rectifi
DELIVERY LOCATION
CLOSING DATE : 02.05.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			PERSONS SHOULD WEAR ALL THE REQUIRED PPE WHILE AT WORK.#ALL MATERIAL AND TOOLS BROUGHT IN SHALL BE DECLARED AT THE POWERSTATION SECURITY GATE AND THE LIST OF THESE ITEMS SHALL BE SIGNED BYDEWA SECURITY. THE COPIES OF THESE DOCU MENTS SHALL BE LODGED WITH THEDEWA ENGINEER IN CHARGE ON DAILY BASIS. THIS DOCUMENT WILL BE THE BASISFOR THE CLEARANCE (GATE PASS) T O TAKE THEM OUT ON COMPLETION OF THE JOB.SERVICE AIR, ELECTRICITY AND WAT						

TOTAL AMOUNT IN WORDS:

TOTAL AMOUNT:

SPECIAL NOTES / INSTRUCTIONS:

PRJ-AUXB 60 tube leak rectification at M Station, DEWA, Jebel Ali.

(BIDDER SHOULD BE 'R' STAMP)

SCOPE OF WORK ATTACHED

Contact Person: Shabbir Ahmad Enulhaque / shabbir.enulhaque@dewa.gov.ae

MATERIAL AND OR SERVICE PROVIDED TO DEWA SHOULD PREFERABLY BE ENERGY EFFICIENT AND ENVIRONMENT FRIENDLY.

Page42 of 43

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332500965
DATE : 18.04.2025
REQ No : 1032501844
REQ TITLE : PRJ-AUXB 60 tube leak rectifi
DELIVERY LOCATION
CLOSING DATE : 02.05.2025
CLOSING TIME : 10:00:00

/ 04-322-5969

STANDARD TERMS & CONDITIONS

- 1) Prices should be 'DDP' delivery duty paid at DEWA stores.
- 2) Quotation to be submitted only in local currency U.A.E Dirhams
- 3) DEWA Standard payment terms is '30 days credit' from the date of acceptance of material
- 4) No DEWA staff or his or her relatives up to third degree should have ownership or partnership in your company, and your participation in DEWA tenders / RFQs should not constitute a Conflict or perceived Conflict of Interest.
- 5) The offered product and/ or services in the Quotation, shall be conforming and in accordance with DEWA Energy Management Policy & EnMS Manual.

SUPPLIER'S REMARKS :

SUPPLIER'S SIGNATURE AND STAMP