

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332500988  
**DATE** : 21.04.2025  
**REQ No** : 1032501084  
**REQ TITLE** : 1-Air Dryer Tubular Heater un  
**DELIVERY LOCATION**  
**CLOSING DATE** : 05.05.2025  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
1		ITEM-00001	MANUFACTURING & SUPPLY OF FLANGED TUBULAR HEATER UNIT FOR AIR DRYER IN I(FOR AIR DRYER IN PH2 IN H-STATION) TYPE: DB-24-RC PURGE. MO DEL:CUSTOMIZED TOTAL POWER LOAD: 18,300W SUPPLY VOLTAGE: 230-400VAC / 3~NNO. OF HEATING COILS ASSEMBLED IN FLANGE: 12 LONG HEATING C OILS: 9, LN950MM, 1700W / 230V SHORT HEATING COILS: 3, LN 750MM, 1000W / 230VMOUNTING FLANGE OD 320MM, THK 6MM, MOUNTING HOLES 8 X Ø 12MM FLANGE TOHEATING COILS MOUNTING BY SPECIAL FABRICATED BOLT ADAPTORS MOC: HEATINGCOILS - INCOLOY 800, FLANGE - ST. STEEL 304/316 GASKET SET TO BE TO BEPROVIDED COIL BUS BAR TERMINAL LINK SET TO BE PROVIDED	2	EA				

TOTAL AMOUNT IN WORDS:

TOTAL AMOUNT:

### SPECIAL NOTES / INSTRUCTIONS:

1-Air Dryer Tubular Heater unit

MATERIAL AND OR SERVICE PROVIDED TO DEWA SHOULD PREFERABLY BE ENERGY EFFICIENT AND ENVIRONMENT FRIENDLY.

Page1 of 2

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332500988  
**DATE** : 21.04.2025  
**REQ No** : 1032501084  
**REQ TITLE** : 1-Air Dryer Tubular Heater un  
**DELIVERY LOCATION**  
**CLOSING DATE** : 05.05.2025  
**CLOSING TIME** : 10:00:00

### STANDARD TERMS & CONDITIONS

- 1) Prices should be 'DDP' delivery duty paid at DEWA stores.
- 2) Quotation to be submitted only in local currency U.A.E Dirhams
- 3) DEWA Standard payment terms is '30 days credit' from the date of acceptance of material
- 4) No DEWA staff or his or her relatives up to third degree should have ownership or partnership in your company, and your participation in DEWA tenders / RFQs should not constitute a Conflict or perceived Conflict of Interest.
- 5) The offered product and/ or services in the Quotation, shall be conforming and in accordance with DEWA Energy Management Policy & EnMS Manual.

**SUPPLIER'S REMARKS :**

**SUPPLIER'S SIGNATURE AND STAMP**