

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332501938
DATE : 31.07.2025
REQ No : 1032503476
REQ TITLE : PS FOR ACUNITS 1032503476
DELIVERY LOCATION : 0022 - M STORE
CLOSING DATE : 06.08.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
1		ITEM-00001	SUPPLY AND INSTALLATION OF 8 NOS OF LV POWER DISTRIBUTION BOXES WITH NECESSARY CABLING AND 1.5" GI CONDUITS AT 08 LOCATIONS IN M-STAT ION AREAS (BLOCK EDGS 10,20 & 30, BSDG, DEMIN PLANT, AIR COMPRESSOR BUILDING, LEB DFO & WWTP) WITH FOLLOWING SPECIFICATIONS WITH 1 PAN EL AT EACH LOCATION.* PANEL SIZE: 500X400X200 MM. ELECTRICAL PANEL SHALL BE STURDY AND WEATHERPROOF. RUST PROOF PAINT SHALL BE APPLIED . PANEL SHALL HAVE RATING OF IP65.* INCOMER: 4P 32A CLASS-C 3PH 380VAC MCB- 1 NO. IN EACH DB.* OUTGOING: 3 NOS. OF 2P 20A CLASS-C 1PH 220VAC MCB ALONG WITH INDIVIDUAL ELCB (2P 20A 300MA 1PH 220VAC).* GROUNDING: STRIPS SHALL BE PROVIDED & CONNECTED TO THE NEAREST GROUNDING POINT WITH 1CX10SQMM GROUNDING CABLE (AS PER SERVICE LINE ITEM#4).* BREAKERS SHALL BE OF ABB/	8	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332501938
DATE : 31.07.2025
REQ No : 1032503476
REQ TITLE : PS FOR ACUNITS 1032503476
DELIVERY LOCATION : 0022 - M STORE
CLOSING DATE : 06.08.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>SIEMENS/SCHNEIDER ELECTRIC/E ATON.* TERMINAL BLOCKS SHALL BE PROVIDED FOR INCOMING- 1 NO. & OUTGOINGCABLES- 3 NOS.* BREAKERS & TERMINAL BLOCKS SHALL BE MOUNTED O N DIN RAIL.* ALL THE COMPONENTS AND THE CABINET SHALL BE LABELLED PROPERLY.* PANELS SHALL BE CONNECTED TO THE DEDICATED LV FEEDERS A SSIGNED INM-STATION BLOCK EDGS 10,20 & 30, BSDG, DEMIN PLANT, AIR COMPRESSORBUILDING, LEB DFO & WWTP AREA SWITCHGEARS BY 4CX4SQMM CA BLE TO BE LAIDIN 1.5"GI CONDUITS.* DRAWINGS SHALL BE SUBMITTED FOR DEWA APPROVAL AND FINAL APPROVEDDRAWINGS TO BE KEPT IN EACH PANEL DRAWING POCKET WITH PROPER LAMINATION.* BEFORE QUOTING, SUPPLIER SHALL VISIT THE SITE (DEWA JEBEL ALISTATION-M) TO GET FAMILIAR WIT H SITE REQUIREMENTS. CONTACT PERSON:MR.MUMTAZ (055-6471260) & E-MAIL ID:</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332501938
DATE : 31.07.2025
REQ No : 1032503476
REQ TITLE : PS FOR ACUNITS 1032503476
DELIVERY LOCATION : 0022 - M STORE
CLOSING DATE : 06.08.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			MUMTAZ.ABRO@DEWA.GOV.AE						
2		ITEM-00001	<p>SUPPLY, LAYING & TERMINATION OF 4CX4.0SQMM CU XLPE INSULATED PVC SHEATHED ARMORED 600/1000V AC CABLES FROM LV SWITCHGEAR FEEDERS TO R</p> <p>OFTOP INSTALLED DISTRIBUTION BOARDS AT 8 LOCATIONS IN M-STATION BLOCKEDGS, BSDG, DEMIN PLANT, ACB, LEB DFO & WWTP.* MAKE: DUCAB/OMA</p> <p>N CABLES/RR CABLE/EQUIVALENT.* ALL CABLE ENTRIES & EXITS SHALL BE SEALED WITH FIRE SEALANT.* IDENTIFICATION LABELS SHALL BE PROVIDED</p> <p>AT REGULAR INTERVALS OF THE CABLES.* PASSING THROUGH THE CONCRETE WALLS SHALL BE MADE BY CORE DRILLING WITHOUT DAMAGING THE EXISTING FACILITY AND AESTHETIC LOOK.* LENGTH OF EACH CABLE CAN BE MEASURED ACTUAL LENGTH. INVOICE WILL BE CERTIFIED FOR THE ACTUAL LENGTH.* CABLES SHALL BE TERMINATED TO THE SOURCE FEEDERS ASSIGNED IN RESPECTIVE BUILDING</p>	400	M				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332501938
DATE : 31.07.2025
REQ No : 1032503476
REQ TITLE : PS FOR ACUNITS 1032503476
DELIVERY LOCATION : 0022 - M STORE
CLOSING DATE : 06.08.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			SWITCHGEARS AND POWER DBS AS PER SERVICE LINEITEM#1.* CABLE SHALL BE LAID IN 1.5" GI CONDUIT AS PER SERVICE LINE ITEM#5.* GLAND HOLES SHALL BE MADE AT BOTH ENDS WITH HOT WORK PERMITS.* N ECESSARY TESTING OF THE CABLES SHALL BE DONE BEFORE ENERGIZATION ANDAFTER ENERGIZATION. (IR, LOOP TEST, OPEN CIRCUIT VOLTAGE, CONNEDVOLTAGE, LOAD CURRENT, ETC)* TERMS & CONDITIONS OF SERVICE LINE ITEM#1 IS APPLICABLE.						
3		ITEM-00001	SUPPLY & INSTALLATION OF 1.5" GI CONDUIT WITH NECESSARY SUPPORTS, FORROUTING THE CABLE BETWEEN THE SWITCHGEAR FEEDERS AND DISTRIBUTION BOX AT08 LOCATIONS AS PER SERVICE LINE ITEM#1, WITH ROUTE LENGTH AS PER ACTUALSITE REQUIREMENT. INVOICE WILL BE CERTIFIED FOR THE ACTUAL LENGTH.	400	M				
4		ITEM-00001	SUPPLY, LAYING & TERMINATION OF 1CX10.0SQMM	400	M				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332501938
DATE : 31.07.2025
REQ No : 1032503476
REQ TITLE : PS FOR ACUNITS 1032503476
DELIVERY LOCATION : 0022 - M STORE
CLOSING DATE : 06.08.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			CU/ PVC 450/750V YELLOW/GREEN STRIPED EARTH CABLE FROM ROOF TOP DISTRIBUTION BOARD TO THE NEAREST EARTHING POINT AT 08 LOCATIONS AS PER SERVICE LINE ITEM#1, WITH ACTUAL LENGTH AS PER SITE REQUIREMENT. INVOICE WILL BE CERTIFIED FOR THE ACTUAL LENGTH.						

TOTAL AMOUNT IN WORDS:

TOTAL AMOUNT:

SPECIAL NOTES / INSTRUCTIONS:

PS FOR ACUNITS

STANDARD TERMS & CONDITIONS

- Prices should be 'DDP' delivery duty paid at DEWA stores.
- Quotation to be submitted only in local currency U.A.E Dirhams
- DEWA Standard payment terms is '30 days credit' from the date of acceptance of material
- No DEWA staff or his or her relatives up to third degree should have ownership or partnership in your company, and your participation in DEWA tenders / RFQs should not constitute a Conflict or perceived Conflict of Interest.

MATERIAL AND OR SERVICE PROVIDED TO DEWA SHOULD PREFERABLY BE ENERGY EFFICIENT AND ENVIRONMENT FRIENDLY.

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332501938
DATE : 31.07.2025
REQ No : 1032503476
REQ TITLE : PS FOR ACUNITS 1032503476
DELIVERY LOCATION : 0022 - M STORE
CLOSING DATE : 06.08.2025
CLOSING TIME : 10:00:00

5) The offered product and/ or services in the Quotation, shall be conforming and in accordance with DEWA Energy Management Policy & EnMS Manual.

SUPPLIER'S REMARKS :

SUPPLIER'S SIGNATURE AND STAMP