

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332501987
DATE : 06.08.2025
REQ No : 1032503772
REQ TITLE : Overhauling & Repairing of 6K
DELIVERY LOCATION
CLOSING DATE : 12.08.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
1		ITEM-00001	OVERHAULING & REPAIR MOTOR DETAILS: 6KW; 400V; 50HZ; 14A; 960RPM; 0.81PH; IP68; HORIZONTAL MOUNTING, MOTOR, MAKE: KSBEQUIPMENT NUMBER: 50348010 QUANTITY: 1 SCOPE OF WORK: 1. DE/NDE INSULATED BEARINGS SUPPLY AS PER OEM. 2. OVERHAULING AND FULL MOTOR REPAIR. 3. REPLACEMENT OF SUBMERSIBLE CABLES AS PER OEM WITH 15-20M LENGTH. 4. INITIAL AND FINAL OVERHAULING INVESTIGATIONS WITNESS BY DEWA TEAM ALONG WITH TECHNICAL DETAILED REPORTS FOR PRE/POST JOB. 5. MOTOR PICKUP AND DELIVERY FROM DEWA BMC RUWAIYAH. 6. STAINLESS STEEL NAMEPLATE. 7. WARR ANTY SHALL BE 12 MONTHS FROM MOTOR DELIVERY AFTER OVERHAULING. COMPLIANCE STATEMENT AGAINST TERMS & CONDITIONS MUST BE PROVIDED. FORM ORE TECHNICAL CLARIFICATIONS, PLEASE REACH SARA: SARA.FAIROOZ@DEWA.GOV.COM, ANNAMALAI: ANNAMALAI@DEWA.GOV.AE	1	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332501987
DATE : 06.08.2025
REQ No : 1032503772
REQ TITLE : Overhauling & Repairing of 6K
DELIVERY LOCATION
CLOSING DATE : 12.08.2025
CLOSING TIME : 10:00:00

TOTAL AMOUNT IN WORDS:

TOTAL AMOUNT:

SPECIAL NOTES / INSTRUCTIONS:

Overhauling <(>&<)> Repairing of 6KW Mushrif Reservoir recirculation motor

STANDARD TERMS & CONDITIONS

- 1) Prices should be 'DDP' delivery duty paid at DEWA stores.
- 2) Quotation to be submitted only in local currency U.A.E Dirhams
- 3) DEWA Standard payment terms is '30 days credit' from the date of acceptance of material
- 4) No DEWA staff or his or her relatives up to third degree should have ownership or partnership in your company, and your participation in DEWA tenders / RFQs should not constitute a Conflict or perceived Conflict of Interest.
- 5) The offered product and/ or services in the Quotation, shall be conforming and in accordance with DEWA Energy Management Policy & EnMS Manual.

SUPPLIER'S REMARKS :

SUPPLIER'S SIGNATURE AND STAMP