

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332501990
DATE : 06.08.2025
REQ No : 1032503774
REQ TITLE : 1- Supply, Fabrication and Ins
DELIVERY LOCATION
CLOSING DATE : 12.08.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
1		ITEM-00001	SUPPLY AND INSTALL 10## NG LINE (SS 316L) FOR GTE # 1 THE SCOPE OF WORKS: -THE SCOPE OF WORKS UNDER THIS CONTRACT IS REPLACEMENT OF EXISTING HIGHPRESSURE NATURAL GAS (NG) SUPPLY PIPING OF GTE#1 GAS TURBINE OF E PHASE-1 WITHIN TURBINE HALL. PIPING IS DESIGNED FOR 30 BARG PRESSURE AND TEMPERATURE 60 DEGC. DETAILED SCOPE OF THE WORKS IS LISTED BELOW BUT NOT LIMITED TO, 1.#TAKE MEASUREMENT AND LAYOUT DETAILS OF EXISTING PIPING AT SITE INCLUDING MAKING ISOMETRIC SKETCH FOR FABRICATION NEW PIPING. 2.#DISMANTLE EXISTING PIPING BETWEEN GT HALL WALL AND GT FUEL GAS KID OF GTE1. PIPING NEEDS TO CUT FROM NG SHUT OFF VALVE OUTLET LINE ELBOW TOUNDER THE TRENCH INSIDE OF GT HALL. 3.#MATERIAL OF CONSTRUCTION OF THE PIPE STAINLESS STEEL SS 316L, SCH-404. 4.#THE MAIN PIPING IS 10-INCH DIAMETER. 5.#ALL WELD	1	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332501990
DATE : 06.08.2025
REQ No : 1032503774
REQ TITLE : 1- Supply, Fabrication and Ins
DELIVERY LOCATION
CLOSING DATE : 12.08.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>JOI NTS SHALL BE BUTT JOINT WITH ROOT TIG WELD AND REMAININGSMAW6.#UNDER THE TRENCH FOR THE PIPE JOINT, MIRROR WELD MAY BE REQUIRED.7.#W ELD JOINTS SHALL BE TESTED 100% BY RADIOGRAPHY AND DYE PENETRANT.THE TESTING WILL BE ARRANGED BY DEWA FREE OF COST. ANY REPAIR WILL BECARRIED OUT BY THE CONTRACTOR.8.#ALL PIPING SHALL BE INTERNALLY AND EXTERNALLY CLEANED BY SANDBLASTING OR GRIT BLASTING TO SA 21/2 GRADE BEFORE FABRICATION.#MECHANICAL CLEANING WHEREVER BLASTING IS NOT POSSIBLE. TEMPORARYCORROSION PROTECTION MAY BE APPLIED FOR T HE INTERNAL SURFACES IF NEEDED.EXTERNAL SURFACES SHALL BE PAINTED WITH ZINC BASED EPOXY PRIMERIMMEDIATELY AFTER BLASTING.9.#STRAIGHT RAW PIPE, SCH 40, STAINLESS STEEL PIPE AND ELBOW REQUIREDFOR THE JOB WILL BE</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332501990
DATE : 06.08.2025
REQ No : 1032503774
REQ TITLE : 1- Supply, Fabrication and Ins
DELIVERY LOCATION
CLOSING DATE : 12.08.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			PROVIDED BY SUPPLIER.10.#GENERALLY, IT IS ASSUMED THAT ALL MATERIALS REQUIRED TO DO THE ABOVE JOB OTHER THAN MENTIONED UNDER ITEM-8 ARE REQUIRED TO BE PROVIDED BY THE CONTRACTOR. HOWEVER, MAJOR ITEMS CONSIDERED ARE LISTED BELOW.A.#10# SCH 40, 90 DEG SEAMLESS STAINLESS-STEEL ELBOW, FIVE NUMBERS REQUIRED AS PER THE SITE ROUTED PIPING LAYOUT.B.#PIPE CLAMPS AS NECESSARY.C.#ALL CONSUMABLES ARE REQUIRED FOR THE JOB ALONG WITH TOOLS AND TACKLES.D.#HYDRO-TESTING OF THE PIPING TO THE EXTENT POSSIBLE BEFORE TIE-IN WITH EXISTING PIPING.E.#PRIMER COATING WITH PAINTING AS PER EXISTING PIPING PAINTING SPECIFICATION AND COLOR CODE.						
2		ITEM-00001	SUPPLY AND INSTALL 10## NG LINE (SS 316L) FOR GTE # 1 THE SCOPE OF WORKS: -THE SCOPE OF WORKS UNDER THIS CONTRACT IS REPLACEMENT OF E	1	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332501990
DATE : 06.08.2025
REQ No : 1032503774
REQ TITLE : 1- Supply, Fabrication and Ins
DELIVERY LOCATION
CLOSING DATE : 12.08.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>EXISTING HIGHPRESSURE NATURAL GAS (NG) SUPPLY PIPING OF GTE#1 GAS TURBINE OF E PHASE-1 WITHIN TURBINE HALL. PIPING IS DESIGNED FOR 30 BARG PRESSURE AND TEMPERATURE 60 DEGC. DETAILED SCOPE OF THE WORKS IS LISTED BELOW BUT NOT LIMITED TO, 1.#TAKE MEASUREMENT AND LAYOUT DETAILS OF EXISTING PIPING AT SITE INCLUDING MAKING ISOMETRIC SKETCH FOR FABRICATION NEW PIPING. 2.#DISMANTLE EXISTING PIPING BETWEEN GT HALL WALL AND GT FUEL GAS KID OF GTE1. PIPING NEEDS TO CUT FROM NG SHUT OFF VALVE OUTLET LINE ELBOW TOWER THE TRENCH INSIDE OF GT HALL. 3.#MATERIAL OF CONSTRUCTION OF THE PIPE STAINLESS STEEL SS 316L, SCH-40. 4.#THE MAIN PIPING IS 10-INCH DIAMETER. 5.#ALL WELD JOINTS SHALL BE BUTT JOINT WITH ROOT TIG WELD AND REMAINING SMAW. 6.#UNDER THE TRENCH FOR THE PIPE JOINT, MIRROR WELD MAY BE</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332501990
DATE : 06.08.2025
REQ No : 1032503774
REQ TITLE : 1- Supply, Fabrication and Ins
DELIVERY LOCATION
CLOSING DATE : 12.08.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>REQUIRED.7.#W ELD JOINTS SHALL BE TESTED 100% BY RADIOGRAPHY AND DYE PENETRANT.THE TESTING WILL BE ARRANGED BY DEWA FREE OF COST. ANY REPAIR WILL BECARRIED OUT BY THE CONTRACTOR.8.#ALL PIPING SHALL BE INTERNALLY AND EXTERNALLY CLEANED BY SANDBLASTING OR GRIT BLASTING TO SA 21/2 GRADE BEFORE FABRICATION.#MECHANICAL CLEANING WHEREVER BLASTING IS NOT POSSIBLE. TEMPORARYCORROSION PROTECTION MAY BE APPLIED FOR T HE INTERNAL SURFACES IF NEEDED.EXTERNAL SURFACES SHALL BE PAINTED WITH ZINC BASED EPOXY PRIMERIMMEDIATELY AFTER BLASTING.9.#STRAIGHT RAW PIPE, SCH 40, STAINLESS STEEL PIPE AND ELBOW REQUIREDFOR THE JOB WILL BE PROVIDED BY SUPPLIER.10.#GENERALLY, IT IS ASSUMED THAT ALL MATERIALS REQUIRED TO DO THEABOVE JOB OTHER THAN MENTIONED UNDER ITEM-8 ARE</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332501990
DATE : 06.08.2025
REQ No : 1032503774
REQ TITLE : 1- Supply, Fabrication and Ins
DELIVERY LOCATION
CLOSING DATE : 12.08.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			REQUIRED TO BE PROVIDED BY THE CONTRACTOR. HOWEVER, MAJOR ITEMS CONSIDERED ARE LISTED BELOW. A.#10# SCH 40, 90 DEG SEAMLESS STAINLESS-STEEL ELBOW, FIVE NUMBERS REQUIRED AS PER THE SITE ROUTED PIPING LAYOUT. B.#PIPE CLAMPS AS NECESSARY. C.#ALL CONSUMABLES ARE REQUIRED FOR THE JOB ALONG WITH TOOLS AND TACKLES. D.#HYDRO-TESTING OF THE PIPING TO THE EXTENT POSSIBLE BEFORE TIE-IN WITH EXISTING PIPING. E.#PRIMER COATING WITH PAINTING AS PER EXISTING PIPING PAINTING SPECIFICATION AND COLOR CODE.						

TOTAL AMOUNT IN WORDS:

TOTAL AMOUNT:

SPECIAL NOTES / INSTRUCTIONS:

1- Supply, Fabrication and Installation of GTE1 NG pipeline from NG skid to turbine hall under trench.

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332501990
DATE : 06.08.2025
REQ No : 1032503774
REQ TITLE : 1- Supply, Fabrication and Ins
DELIVERY LOCATION
CLOSING DATE : 12.08.2025
CLOSING TIME : 10:00:00

FOR FURTHER DETAILS, PLEASE CONTACT ASM MYNUDDIN (0503620814)
MYNUDDIN.HOSSAIN@DEWA.GOV.AE /MARWAN AL MHEIRI (0501136322) (MARWAN.AL
MHEIRI@DEWA.GOV.AE), AHMED ZAKARIA (ahmed.eldaly@dewa.gov.ae), 0524781810

STANDARD TERMS & CONDITIONS

- 1) Prices should be 'DDP' delivery duty paid at DEWA stores.
- 2) Quotation to be submitted only in local currency U.A.E Dirhams
- 3) DEWA Standard payment terms is '30 days credit' from the date of acceptance of material
- 4) No DEWA staff or his or her relatives up to third degree should have ownership or partnership in your company, and your participation in DEWA tenders / RFQs should not constitute a Conflict or perceived Conflict of Interest.
- 5) The offered product and/ or services in the Quotation, shall be conforming and in accordance with DEWA Energy Management Policy & EnMS Manual.

SUPPLIER'S REMARKS :

SUPPLIER'S SIGNATURE AND STAMP